



464 Valley Brook Avenue, Lyndhurst NJ 07071
129 Sea Girt Avenue, Manasquan NJ 08736
Phone: (800) 423-0766 • Fax: (201) 438-1798
www.mccabeenv.com

LEAD & COPPER IN DRINKING WATER TESTING REPORT

Conducted for:

Greater Bergen Community Action
392 Main Street
Hackensack, New Jersey 07601

Conducted at:

Lincoln Park Pre-School Center
330 Duncan Avenue
Jersey City, New Jersey 07307

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: July 23, 2025

MES PROJECT NO.: 25-05229

Prepared by:

A handwritten signature in blue ink, reading 'Gerard D'Alessio'.

**Gerard D'Alessio
Environmental Scientist**

Signed for the Company by:

A handwritten signature in blue ink, reading 'John H. Chiaviello'.

**John H. Chiaviello
Vice President**

TABLE OF CONTENTS

	<u>Page</u>
1.0 INTRODUCTION	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS	2
5.0 DISCUSSION AND CONCLUSION	5

APPENDIX A

Laboratory Certificates of Analysis
&
Sample Chain of Custody Forms

APPENDIX B

Sampling Plan Attachments

APPENDIX C

Sample Location Drawing

1.0 INTRODUCTION

McCabe Environmental Services, L.L.C. (McCabe) was retained by Greater Bergen Community Action (Client) to conduct lead & copper in drinking water testing at Lincoln Park Pre-School Center located at 330 Duncan Avenue, Jersey City, New Jersey 07307.

The project information is as follows:

<u>Client Name:</u>	Greater Bergen Community Action
<u>Contact Person:</u>	Mr. Raul Torres
<u>Project Name:</u>	Lincoln Park Pre-School Center Lead & Copper in Drinking Water
<u>Project Location:</u>	330 Duncan Avenue Jersey City, New Jersey 07307
<u>Date(s) of Service:</u>	June 13, 2025
<u>McCabe Personnel:</u>	Kevin Brossok

2.0 SCOPE OF WORK

Drinking water testing was performed at Lincoln Park Pre-School Center at 330 Duncan Avenue, Jersey City, New Jersey 07307 on June 13, 2025. The purpose of the testing was to determine if the building's plumbing was having an adverse impact on water quality, specifically with regard to lead and copper concentrations. Samples were collected from various potential drinking water outlets located throughout the building.

3.0 PROCEDURES

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. All samples were collected into 250 mL sterile bottles containing nitric acid preservative, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead and copper in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards. The MCL for Copper is set at 1300 ppb.

4.0 TABLE OF SAMPLE RESULTS

The following table presents all lead and copper sample results in order of sample identification:

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
LP-01	Classroom 101 Food Prep Sink	< 0.5	Pass	Pass	18	Pass
LP-02	Classroom 101 Porcelain Sink	< 0.5	Pass	Pass	< 5	Pass
LP-03	Classroom 101/102 Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-04	Classroom 102 Food Prep Sink	< 0.5	Pass	Pass	< 5	Pass
LP-05	Classroom 103 Food Prep Sink	< 0.5	Pass	Pass	9	Pass
LP-06	Classroom 103 Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-07	Classroom 104 Food Prep Sink	< 0.5	Pass	Pass	15	Pass
LP-08	Classroom 104/105 Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-09	Classroom 105 Food Prep Sink	< 0.5	Pass	Pass	8	Pass
LP-10	Classroom 106 Food Prep Sink	< 0.5	Pass	Pass	17	Pass
LP-11	Classroom 106/107 Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-12	Classroom 107 Food Prep Sink	< 0.5	Pass	Pass	13	Pass

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
LP-13	2 nd Floor Kitchen Sink (Left)	< 0.5	Pass	Pass	< 5	Pass
LP-14	Classroom 202 Food Prep Sink	< 0.5	Pass	Pass	25	Pass
LP-15	Classroom 202 Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-16	Classroom 203 Food Prep Sink	< 0.5	Pass	Pass	18	Pass
LP-17	Classroom 203 Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-18	Classroom 204 Food Prep Sink	< 0.5	Pass	Pass	25	Pass
LP-19	Classroom 204 Bathroom Sink	< 0.5	Pass	Pass	6	Pass
LP-20	Main Office 205 Staff Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-21	Main Office Room 208 Bathroom Sink	< 0.5	Pass	Pass	7	Pass
LP-22	Teacher Workroom 212 Sink	Out of Service				
LP-23	Teacher Workroom 212 Bathroom Sink	Out of Service				
LP-24	Room 210 Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-25	Classroom 201 Food Prep Sink	< 0.5	Pass	Pass	11	Pass

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
LP-26	Classroom 201 Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-27	2 nd Floor Kitchen Sink (Right)	< 0.5	Pass	Pass	< 5	Pass
LP-28	2 nd Floor Janitor Closet SJ1 Sink	< 0.5	Pass	Pass	6	Pass
LP-29	Classroom 101 Porcelain Sink	Out of Service				
LP-30	Classroom 102 Porcelain Sink	< 0.5	Pass	Pass	< 5	Pass
LP-31	Classroom 103 Porcelain Sink	< 0.5	Pass	Pass	< 5	Pass
LP-32	Classroom 104 Porcelain Sink	< 0.5	Pass	Pass	< 5	Pass
LP-33	Classroom 105 Porcelain Sink	< 0.5	Pass	Pass	< 5	Pass
LP-34	Classroom 106 Porcelain Sink	< 0.5	Pass	Pass	< 5	Pass
LP-35	Classroom 107 Porcelain Sink	< 0.5	Pass	Pass	< 5	Pass
LP-36	2 nd Floor Kitchen Handwashing Sink	< 0.5	Pass	Pass	< 5	Pass
LP-37	2 nd Floor Nurses Office Sink	0.7	Pass	Pass	36	Pass
LP-38	1 st Floor Janitor Closet FJ1 Sink	< 0.5	Pass	Pass	< 5	Pass

5.0 DISCUSSION AND CONCLUSION

A total of thirty-five (35) samples were collected from Lincoln Park Pre-School Center located at 330 Duncan Avenue, Jersey City, New Jersey 07307. All samples were found to be less than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb, as well as the EPA Lead and Copper Rule standard of 15 ppb. All samples were also found to be less than the 1300 ppb standard for copper.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building's plumbing is not having an adverse impact on water quality.

APPENDIX A

**LABORATORY CERTIFICATES OF ANALYSIS
&
SAMPLE CHAIN OF CUSTODY FORMS**



Monday, June 23, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
SDG ID: GCT52034
Sample ID#s: CT52034 - CT52068

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Phyllis Shiller".

Phyllis Shiller

Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

June 23, 2025

SDG I.D.: GCT52034

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN

Client Id	Lab Id	Matrix	Col Date
LP-01	CT52034	DRINKING WATER	06/13/25 7:10
LP-02	CT52035	DRINKING WATER	06/13/25 7:11
LP-03	CT52036	DRINKING WATER	06/13/25 7:12
LP-04	CT52037	DRINKING WATER	06/13/25 7:14
LP-05	CT52038	DRINKING WATER	06/13/25 7:16
LP-06	CT52039	DRINKING WATER	06/13/25 7:17
LP-07	CT52040	DRINKING WATER	06/13/25 7:20
LP-08	CT52041	DRINKING WATER	06/13/25 7:22
LP-09	CT52042	DRINKING WATER	06/13/25 7:24
LP-10	CT52043	DRINKING WATER	06/13/25 7:25
LP-11	CT52044	DRINKING WATER	06/13/25 7:27
LP-12	CT52045	DRINKING WATER	06/13/25 7:28
LP-13	CT52046	DRINKING WATER	06/13/25 7:30
LP-14	CT52047	DRINKING WATER	06/13/25 7:34
LP-15	CT52048	DRINKING WATER	06/13/25 7:35
LP-16	CT52049	DRINKING WATER	06/13/25 7:36
LP-17	CT52050	DRINKING WATER	06/13/25 7:37
LP-18	CT52051	DRINKING WATER	06/13/25 7:38
LP-19	CT52052	DRINKING WATER	06/13/25 7:39
LP-20	CT52053	DRINKING WATER	06/13/25 7:40
LP-21	CT52054	DRINKING WATER	06/13/25 7:41
LP-24	CT52055	DRINKING WATER	06/13/25 7:43
LP-25	CT52056	DRINKING WATER	06/13/25 7:44
LP-26	CT52057	DRINKING WATER	06/13/25 7:45
LP-27	CT52058	DRINKING WATER	06/13/25 7:31
LP-28	CT52059	DRINKING WATER	06/13/25 7:33
LP-30	CT52060	DRINKING WATER	06/13/25 7:45
LP-31	CT52061	DRINKING WATER	06/13/25 7:18
LP-32	CT52062	DRINKING WATER	06/13/25 7:21
LP-33	CT52063	DRINKING WATER	06/13/25 7:23



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

June 23, 2025

SDG I.D.: GCT52034

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN

Client Id	Lab Id	Matrix	Col Date
LP-34	CT52064	DRINKING WATER	06/13/25 7:26
LP-35	CT52065	DRINKING WATER	06/13/25 7:29
LP-36	CT52066	DRINKING WATER	06/13/25 7:32
LP-37	CT52067	DRINKING WATER	06/13/25 7:42
LP-38	CT52068	DRINKING WATER	06/13/25 7:19



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:10
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52034

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	18	5	2	ppb	1300		1000	06/18/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/18/25	CPP	E200.8
Total Metal Digestion	Completed							06/17/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:11
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52035

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/18/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/18/25	CPP	E200.8
Total Metal Digestion	Completed							06/17/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:12
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52036

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/18/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/18/25	CPP	E200.8
Total Metal Digestion	Completed							06/17/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:14
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52037

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/18/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/18/25	CPP	E200.8
Total Metal Digestion	Completed							06/17/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:16
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52038

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	9	5	2	ppb	1300		1000	06/18/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/18/25	CPP	E200.8
Total Metal Digestion	Completed							06/17/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:17
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52039

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/18/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/18/25	CPP	E200.8
Total Metal Digestion	Completed							06/17/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:20
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52040

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	15	5	2	ppb	1300		1000	06/18/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/18/25	CPP	E200.8
Total Metal Digestion	Completed							06/17/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:22
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52041

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:24
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52042

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	8	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:25
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52043

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	17	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:27
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52044

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:28
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52045

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	13	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:30
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52046

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:34
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52047

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	25	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:35
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52048

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:36
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52049

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	18	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:37
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52050

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:38
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52051

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	25	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:39
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52052

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	6	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:40
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52053

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:41
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52054

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	7	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:43
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52055

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-24

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:44
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52056

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	11	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:45
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52057

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-26

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:31
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52058

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-27

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:33
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52059

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-28

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	6	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:45
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52060

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-30

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	23	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	JM	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:18
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52061

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-31

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	CPP	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:21
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52062

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-32

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	CPP	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:23
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52063

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-33

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	CPP	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:26
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52064

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-34

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	CPP	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:29
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52065

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-35

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	CPP	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:32
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52066

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-36

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	CPP	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:42
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52067

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-37

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	36	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	0.7	0.5	2	ppb	15			06/19/25	CPP	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 23, 2025

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#:

Custody Information

Collected by: KB
Received by: CP
Analyzed by: see "By" below

Date

06/13/25
06/13/25

Time

7:19
18:00

Laboratory Data

SDG ID: GCT52034
Phoenix ID: CT52068

Project ID: 25-05229 GREATER BERGEN COMM.-LINCOLN
Client ID: LP-38

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300		1000	06/19/25	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			06/19/25	CPP	E200.8
Total Metal Digestion	Completed							06/18/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 23, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager

Analysis Report - Summary

June 23, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT52034




Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 25-05229 Greater Bergen Comm.-lincoln								
CT52034	LP-01	06/13/25	Lead	< 0.5	0.5	ppb	06/18/25	E200.8
CT52035	LP-02	06/13/25	Lead	< 0.5	0.5	ppb	06/18/25	E200.8
CT52036	LP-03	06/13/25	Lead	< 0.5	0.5	ppb	06/18/25	E200.8
CT52037	LP-04	06/13/25	Lead	< 0.5	0.5	ppb	06/18/25	E200.8
CT52038	LP-05	06/13/25	Lead	< 0.5	0.5	ppb	06/18/25	E200.8
CT52039	LP-06	06/13/25	Lead	< 0.5	0.5	ppb	06/18/25	E200.8
CT52040	LP-07	06/13/25	Lead	< 0.5	0.5	ppb	06/18/25	E200.8
CT52041	LP-08	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52042	LP-09	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52043	LP-10	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52044	LP-11	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52045	LP-12	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52046	LP-13	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52047	LP-14	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52048	LP-15	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52049	LP-16	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52050	LP-17	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52051	LP-18	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52052	LP-19	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52053	LP-20	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52054	LP-21	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52055	LP-24	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52056	LP-25	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52057	LP-26	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52058	LP-27	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CT52059	LP-28	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52060	LP-30	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52061	LP-31	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52062	LP-32	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52063	LP-33	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52064	LP-34	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52065	LP-35	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52066	LP-36	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8
CT52067	LP-37	06/13/25	Lead	0.7	0.5	ppb	06/19/25	E200.8
CT52068	LP-38	06/13/25	Lead	< 0.5	0.5	ppb	06/19/25	E200.8

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit


 Phyllis Shiller
 Laboratory Director
 June 23, 2025



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



QA/QC Report

June 23, 2025

QA/QC Data

SDG I.D.: GCT52034

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 789427A (mg/L), QC Sample No: CT52031 (CT52034, CT52035, CT52036, CT52037, CT52038, CT52039, CT52040)

ICP MS Metals - Aqueous

Copper	BRL	0.0005				109			NC				
Lead	BRL	0.0001				99.8			89.4				

Comment:

This batch does not include a duplicate.

QA/QC Batch 789648 (mg/L), QC Sample No: CT52041 (CT52041, CT52042, CT52043, CT52044, CT52045, CT52046, CT52047, CT52048, CT52049, CT52050)

ICP MS Metals - Aqueous

Copper	BRL	0.0005	<0.005	0.0040	NC	109			113				
Lead	BRL	0.0001	<0.0005	<0.0001	NC	97.0			99.8				

QA/QC Batch 789648A (mg/L), QC Sample No: CT52051 (CT52051, CT52052, CT52053, CT52054, CT52055, CT52056, CT52057, CT52058, CT52059, CT52060)

ICP MS Metals - Aqueous

Copper	BRL	0.0005				109			117				
Lead	BRL	0.0001				97.0			100				

Comment:

This batch does not include a duplicate.


QA/QC Batch 789649 (mg/L), QC Sample No: CT52061 (CT52061, CT52062, CT52063, CT52064, CT52065, CT52066, CT52067, CT52068)

ICP MS Metals - Aqueous

Copper	BRL	0.001	<0.005	0.0037	NC	115			114				
Lead	BRL	0.0001	<0.0005	<0.0001	NC	102			97.8				

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


Phyllis Shiller, Laboratory Director
June 23, 2025

Monday, June 23, 2025

Criteria: NJ: DW
State: NJ

Sample Criteria Exceedances Report
GCT52034 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

June 23, 2025

SDG I.D.: GCT52034

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

2.1st WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201) 438-4839 FAX: (201) 438-1798

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action - Lincoln Park Pre School Center		SITE ADDRESS: 330 Duncan Avenue, Jersey City, New Jersey 07307	
FIELD INSPECTOR'S NAME: Kevin Brossok		TURNAROUND TIME REQUESTED: 2 Week	
MES PROJECT #: 25-05229	SAMPLE DATE: 6/13/25		

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW 52034	LP-01	Classroom 101 Food Prepsink	7:10	COPPER - 200.7 LEAD - 200.8
DW 52035	LP-02	Classroom 101 Porcelainsink	7:11	COPPER - 200.7 LEAD - 200.8
DW 52036	LP-03	Classroom 101/102 Bathroom Sink	7:12	COPPER - 200.7 LEAD - 200.8
DW 52037	LP-04	Classroom 102 Food Prepsink	7:14	COPPER - 200.7 LEAD - 200.8
DW 52038	LP-05	Classroom 103 Food Prepsink	7:16	COPPER - 200.7 LEAD - 200.8
DW 52039	LP-06	Classroom 103 Bathroom Sink	7:17	COPPER - 200.7 LEAD - 200.8
DW 52040	LP-07	Classroom 104 Food Prepsink	7:20	COPPER - 200.7 LEAD - 200.8
DW 52041	LP-08	Classroom 104/105 Bathroom Sink	7:22	COPPER - 200.7 LEAD - 200.8
DW 52042	LP-09	Classroom 105 Food Prepsink	7:24	COPPER - 200.7 LEAD - 200.8
DW 52043	LP-10	Classroom 106 Food Prepsink	7:25	COPPER - 200.7 LEAD - 200.8

Relinquished by (Print): Kevin Brossok	Date: 6/13/25	Time: 1:01 pm	Received by: (Print) J. Demers	Date: 6-13	Time: 1303
Signature: <i>Kevin Brossok</i>			Signature: <i>J. Demers</i>		
Relinquished by (Print)	Date:	Time:	Received by: (Print) <i>J. Demers</i>	Date:	Time:
Signature: <i>[Signature]</i>			Signature: <i>[Signature]</i>		

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

[Signature]

NJ Certified WBE

Aduy fee 6/13/25 1800

2.1st WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201) 438-4839 FAX: (201) 438-1798

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action - Lincoln Park Pre School Center		SITE ADDRESS: 330 Duncan Avenue, Jersey City, New Jersey 07307	
FIELD INSPECTOR'S NAME: Kevin Brossok		TURNAROUND TIME REQUESTED: 2 Week	
MES PROJECT #: 25-05229	SAMPLE DATE: 6/13/25		

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW 52044	LP-11	Classroom 106/107 Bathroom Sink	7:27	COPPER - 200.7 LEAD - 200.8
DW 52045	LP-12	Classroom 107 Food Prep Sink	7:28	COPPER - 200.7 LEAD - 200.8
DW 52046	LP-13	2 nd Floor Kitchen Sink (Left)	7:30	COPPER - 200.7 LEAD - 200.8
DW 52047	LP-14	Classroom 202 Food Prep Sink	7:34	COPPER - 200.7 LEAD - 200.8
DW 52048	LP-15	Classroom 202 Bathroom Sink	7:35	COPPER - 200.7 LEAD - 200.8
DW 52049	LP-16	Classroom 203 Food Prep Sink	7:36	COPPER - 200.7 LEAD - 200.8
DW 52050	LP-17	Classroom 203 Bathroom Sink	7:37	COPPER - 200.7 LEAD - 200.8
DW 52051	LP-18	Classroom 204 Food Prep Sink Teachers Lounge 212 Bathroom Sink	7:38	COPPER - 200.7 LEAD - 200.8
DW 52052	LP-19	Classroom 204 Bathroom Sink	7:39	COPPER - 200.7 LEAD - 200.8
DW 52053	LP-20	Main Office 205 Staff Bathroom Sink	7:40	COPPER - 200.7 LEAD - 200.8

Relinquished by (Print): Kevin Brossok	Date: 6/13/25	Time: 1:01 PM	Received by: (Print) J. Deneo	Date: 6-13	Time: 1303
Signature: <i>Kevin Brossok</i>			Signature: <i>J. Deneo</i>		
Relinquished by (Print)	Date:	Time:	Received by: (Print) Deneo	Date:	Time:
Signature: <i>OP</i>			Signature: <i>Deneo</i>		

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

Deneo
NJ Certified WBE

July See 6/13/25 1800

2.1st WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action - Lincoln Park Pre School Center		SITE ADDRESS: 330 Duncan Avenue, Jersey City, New Jersey 07307	
FIELD INSPECTOR'S NAME: Kevin Brossok		TURNAROUND TIME REQUESTED: 2 Week	
MES PROJECT #: 25-05229	SAMPLE DATE: 6/13/25		

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW 52054	LP-21	Main Office Room ²¹⁰ 210 Bathroom Sink	7:41	COPPER - 200.7 LEAD - 200.8
DW	LP-22	Teacher work room 212 Sink (KB)	7:43	COPPER - 200.7 LEAD - 200.8
DW	LP-23	Teacher work room 212 Bathroom Sink (KB)		COPPER - 200.7 LEAD - 200.8
DW 52055	LP-24	Room 208 Bathroom Sink	7:43	COPPER - 200.7 LEAD - 200.8
DW 52056	LP-25	Classroom 201 Food Prep Sink	7:44	COPPER - 200.7 LEAD - 200.8
DW 52057	LP-26	Classroom 201 Bathroom Sink	7:45	COPPER - 200.7 LEAD - 200.8
DW 52058	LP-27	2nd Floor Kitchen Sink (Right)	7:31	COPPER - 200.7 LEAD - 200.8
DW 52059	LP-28	2nd Floor Janitor Closet 551 Sink	7:33	COPPER - 200.7 LEAD - 200.8
DW	LP-29	Classroom 101 Porcelain Sink (KB)		COPPER - 200.7 LEAD - 200.8
DW 52060	LP-30	Classroom 102 Porcelain Sink	7:15	COPPER - 200.7 LEAD - 200.8

Relinquished by (Print): Kevin Brossok	Date: 6/13/25	Time: 1:01 PM	Received by: (Print) J. Deneers	Date: 6-13 2025	Time: 1303
Signature: <i>Kevin Brossok</i>			Signature: <i>J. Deneers</i>		
Relinquished by (Print)	Date:	Time:	Received by: (Print) J. Deneers	Date: 6/13/25	Time: 2:30 PM
Signature: <i>KB</i>			Signature: <i>J. Deneers</i>		

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

Abby Lee 6/13/25 1800

2.1⁰⁰ WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action - Lincoln Park Pre School Center		SITE ADDRESS: 330 Duncan Avenue, Jersey City, New Jersey 07307	
FIELD INSPECTOR'S NAME: Kevin Brossok		TURNAROUND TIME REQUESTED: 2 Week	
MES PROJECT #: 25-05229	SAMPLE DATE: 6/13/25		

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW 52061	LP-31	Class room 103 Porcelain SINK	7:18	COPPER - 200.7 LEAD - 200.8
DW 52062	LP-32	Class room 104 Porcelain SINK	7:21	COPPER - 200.7 LEAD - 200.8
DW 52063	LP-33	Class room 105 Porcelain SINK	7:21 7:23	COPPER - 200.7 LEAD - 200.8
DW 52064	LP-34	Class room 106 Porcelain SINK	7:26	COPPER - 200.7 LEAD - 200.8
DW 52065	LP-35	Class room 107 Porcelain SINK	7:29	COPPER - 200.7 LEAD - 200.8
DW 52066	LP-36	2nd Floor Kitchen Handwashing SINK	7:32	COPPER - 200.7 LEAD - 200.8
DW 52067	LP-37	2nd Floor Nurses Office SINK	7:42	COPPER - 200.7 LEAD - 200.8
DW 52068	LP-38	1st Floor Janitor Closet FJI SINK	7:19	COPPER - 200.7 LEAD - 200.8
DW				COPPER - 200.7 LEAD - 200.8
DW				COPPER - 200.7 LEAD - 200.8

Relinquished by (Print): Kevin Brossok	Date: 6/13/25	Time: 10:1 PM	Received by: (Print) J. Demers	Date: 6/13/25	Time: 1303
Signature: <i>Kevin Brossok</i>			Signature: <i>J. Demers</i>		
Relinquished by (Print)	Date:	Time:	Received by: (Print) <i>Demers</i>	Date: 6/13/25	Time: 2:00 PM
Signature: <i>Demers</i>			Signature: <i>Demers</i>		

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

Demers
NJ Certified WBE

Andy Lee 6/13/25 1300

APPENDIX B

SAMPLING PLAN ATTACHMENTS

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Lincoln Park Pre-School Center	6/13/2025	Phoenix	Water Fountains No Longer In Use

Attachment B – Plumbing Profile

Note: Complete for each school. For additional information see the USEPA publication, “The 3Ts for Reducing Lead in Drinking Water in Schools”

Name of School: Lincoln Park Grade Levels: Childcare Facility

Address: 330 Duncan Avenue, Jersey City, New Jersey

Individual school project officer Signature: Kevin Brossok Date: 06/13/2025

Questions	Answers	
Background Information		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	2016	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Unknown	
3. Where are the most recent plumbing repairs and replacements?	Location: None	Description:
4. With what materials is the service connection (the pipe that carries water to the school from the public water system’s main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Coated Steel (Black w/ Ridges) Charlotte Pipe Location: Northeast Wall	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N Type:	Location:

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	No
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: • Name of contaminant(s) • Concentrations found • pH level Is testing done regularly at the building?	No
11. Other plumbing background questions include: • Are blueprints of the building available? • Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”? Are renovations planned for any of the plumbing system?	No

Questions	Answers
Walk-Through <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>	
1. Confirm the material of Service Line visually.	Done
2. Confirm the presence of POE or POU treatment.	Done
3. What are the potable water pipes made of in your facility? • Lead • Plastic • Galvanized Metal • Cast Iron • Copper • Other Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Copper & PVC
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N Location: Northeast Wall Electric Meter Room
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory. Done

Questions	Answers	
7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit? Recalled Drinking Water Fountains Make and Model	☒ Y / ☐ N Type	
8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected? Note the locations of water outlets.	Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory. No	
9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily? Permanently Temporarily	Y / ☒ N Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory. Type/ Location	Description

Attachment C – Drinking Water Outlet Inventory

Name of School: Lincoln Park Pre-School Center

Address: 330 Duncan Avenue, Jersey City, New Jersey 07307

Grade Levels: Childcare Facility

Year School Constructed: 2016

Renovated/Additions: NA

Individual school project officer Name/Signature: Kevin Brossok

Date Completed: 6/13/2025

# ¹	Type	Location	Code	Operational ² (Y/N)	Signs of Corrosion ³ (Y/N)	Filter ⁴ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
	01	Sink	Classroom 101 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	02	Sink	Classroom 101 Porcelain Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	03	Sink	Classroom 101/102 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	04	Sink	Classroom 102 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	05	Sink	Classroom 103 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	06	Sink	Classroom 103 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.

	07	Sink	Classroom 104 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	08	Sink	Classroom 104/105 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	09	Sink	Classroom 105 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	10	Sink	Classroom 106 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	11	Sink	Classroom 106/107 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	12	Sink	Classroom 107 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	13	Sink	2 nd Floor Kitchen Sink (Left)	Y	N	N	N	N	Y	N	N	N/A	N/A
	14	Sink	Classroom 202 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	15	Sink	Classroom 202 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	16	Sink	Classroom 203 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	17	Sink	Classroom 203 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	18	Sink	Classroom 204 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	19	Sink	Classroom 204 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A

	20	Sink	Main Office 205 Staff Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	21	Sink	Main Office Room 208 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	22	Sink	Teacher Workroom 212 Sink	Y	N	N	N	N	Y	N	N	N/A	Out of Service
	23	Sink	Teacher Workroom 212 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	Out of Service
	24	Sink	Room 210 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	25	Sink	Classroom 201 Food Prep Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	26	Sink	Classroom 201 Bathroom Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	27	Sink	2 nd Floor Kitchen Sink (Right)	Y	N	N	N	N	Y	N	N	N/A	N/A
	28	Sink	2 nd Floor Janitor Closet SJ1 Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	29	Sink	Classroom 101 Porcelain Sink	Y	N	N	N	N	Y	N	N	N/A	Out of Service
	30	Sink	Classroom 102 Porcelain Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	31	Sink	Classroom 103 Porcelain Sink	Y	N	N	N	N	Y	N	N	N/A	N/A

	32	Sink	Classroom 104 Porcelain Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	33	Sink	Classroom 105 Porcelain Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	34	Sink	Classroom 106 Porcelain Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	35	Sink	Classroom 107 Porcelain Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	36	Sink	2 nd Floor Kitchen Handwashing Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	37	Sink	2 nd Floor Nurses Office Sink	Y	N	N	N	N	Y	N	N	N/A	N/A
	38	Sink	1 st Floor Janitors Closet FJ1 Sink	Y	N	N	N	N	Y	N	N	N/A	N/A

Attachment D - Filter Inventory

Name of School: Lincoln Park Pre-School Center Grade Levels: Childcare Facility

Address: 330 Duncan Avenue, Jersey City, New Jersey 07307

Individual School Project Officer: Kevin Brossok

Date: 6/13/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
LP-01	N/A	N/A	N/A	N/A	N/A
LP-02	N/A	N/A	N/A	N/A	N/A
LP-03	N/A	N/A	N/A	N/A	N/A
LP-04	N/A	N/A	N/A	N/A	N/A
LP-05	N/A	N/A	N/A	N/A	N/A
LP-06	N/A	N/A	N/A	N/A	N/A
LP-07	N/A	N/A	N/A	N/A	N/A
LP-08	N/A	N/A	N/A	N/A	N/A
LP-09	N/A	N/A	N/A	N/A	N/A
LP-10	N/A	N/A	N/A	N/A	N/A
LP-11	N/A	N/A	N/A	N/A	N/A
LP-12	N/A	N/A	N/A	N/A	N/A
LP-13	N/A	N/A	N/A	N/A	N/A
LP-14	N/A	N/A	N/A	N/A	N/A
LP-15	N/A	N/A	N/A	N/A	N/A
LP-16	N/A	N/A	N/A	N/A	N/A
LP-17	N/A	N/A	N/A	N/A	N/A
LP-18	N/A	N/A	N/A	N/A	N/A
LP-19	N/A	N/A	N/A	N/A	N/A
LP-20	N/A	N/A	N/A	N/A	N/A
LP-21	N/A	N/A	N/A	N/A	N/A
LP-24	N/A	N/A	N/A	N/A	N/A
LP-25	N/A	N/A	N/A	N/A	N/A
LP-26	N/A	N/A	N/A	N/A	N/A
LP-27	N/A	N/A	N/A	N/A	N/A

LP-28	N/A	N/A	N/A	N/A	N/A
LP-30	N/A	N/A	N/A	N/A	N/A
LP-31	N/A	N/A	N/A	N/A	N/A
LP-32	N/A	N/A	N/A	N/A	N/A
LP-33	N/A	N/A	N/A	N/A	N/A
LP-34	N/A	N/A	N/A	N/A	N/A
LP-35	N/A	N/A	N/A	N/A	N/A
LP-36	N/A	N/A	N/A	N/A	N/A
LP-37	N/A	N/A	N/A	N/A	N/A
LP-38	N/A	N/A	N/A	N/A	N/A

Attachment E – Flushing Log

Name of School: Lincoln Park Pre-School Center

Address: 330 Duncan Avenue, Jersey City, New Jersey 07307

Grade Levels: Childcare Facility

Individual School Project Officer: Kevin Brossok

Date: 6/13/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Classroom 101 Food Prep Sink	LP-01	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 101 Porcelain Sink	LP-02	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 101/102 Bathroom Sink	LP-03	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 102 Food Prep Sink	LP-04	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 103 Food Prep Sink	LP-05	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 103 Bathroom Sink	LP-06	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 104 Food Prep Sink	LP-07	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 104/105 Bathroom Sink	LP-08	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 105 Food Prep Sink	LP-09	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 106 Food Prep Sink	LP-010	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 106/107 Bathroom Sink	LP-11	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 107 Food Prep Sink	LP-12	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Kitchen Sink (Left)	LP-13	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 202 Food Prep Sink	LP-14	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 202	LP-15	June 5,	3:00 pm	2-3 minutes	Water Sampling

Lincoln Park Pre-School Center Sampling Plan

Bathroom Sink		2025			
Classroom 203 Food Prep Sink	LP-16	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 203 Bathroom Sink	LP-17	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 204 Food Prep Sink	LP-18	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 204 Bathroom Sink	LP-19	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Main Office 205 Staff Bathroom Sink	LP-20	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Main Office Room 208 Bathroom Sink	LP-21	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Room 210 Bathroom Sink	LP-24	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 201 Food Prep Sink	LP-25	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 201 Bathroom Sink	LP-26	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Kitchen Sink (Right)	LP-27	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Janitor Closet SJ1 Sink	LP-28	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 102 Porcelain Sink	LP-30	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 103 Porcelain Sink	LP-31	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 104 Porcelain Sink	LP-32	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 105 Porcelain Sink	LP-33	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 106 Porcelain Sink	LP-34	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
Classroom 107 Porcelain Sink	LP-35	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Kitchen Handwashing Sink	LP-36	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Nurses Office Sink	LP-37	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling
1 st Floor Janitor Closet FJ1 Sink	LP-38	June 5, 2025	3:00 pm	2-3 minutes	Water Sampling

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE LINCOLN PARK DISTRICT REPRESENTATIVE:		
School Name: Lincoln Park Pre-School Center		
Sample Collection Address: 330 Duncan Avenue, Jersey City, New Jersey 07307		
Water was last used:	Time: 3:00 PM	Date: 6/12/2025
Sample commencement:	Time: 7:00 AM	Date: 6/13/2025
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Kevin Brossok		6/13/2025
Signature		Date

DRINKING WATER TESTING CHECKLIST

Note: This form is for child care centers that are supplied water by a community water system.

•PROGRAMS IN OPERATING PUBLIC SCHOOLS ARE NOT REQUIRED TO COMPLETE THIS FORM•

CHILD CARE CENTER INFORMATION


Name of Child Care Center:		License ID:	
Site Address of Center:	Building # and Street:	Municipality:	County:
Sponsor/Sponsor Representative:		Phone Number:	Email:

CERTIFICATION OF COMPLIANCE WITH LEAD & COPPER SAMPLING AT THE ABOVE CHILD CARE CENTER

Sampling Date(s):	
1. ☐ YES ☐ NO	Does the center have a signed contract with a New Jersey Certified Drinking Water Laboratory for lead & copper analysis?
2. ☐ YES ☐ NO	Is there an onsite water outlet assessment in accordance with technical guidance?
3. ☐ YES ☐ NO	Is there a floor plan in accordance with technical guidance?
4. ☐ YES ☐ NO Sample Date:	Were all the drinking water outlets in the center where a child or staff has or may have access (including food preparation and outside drinking water outlets) sampled?
5. ☐ YES ☐ NO Sample Date:	Were at least 50% of all indoor water faucets utilized by the center sampled?
6. ☐ YES ☐ NO	Does the child care center have the chain of custody and analytical reports for all drinking water outlets sampled? Please attach copies.
7. ☐ YES ☐ NO	Was all the drinking water outlets sampled in the sequence determined by the floor plan beginning with the outlet closest to the point of entry?
8. ☐ YES ☐ NO	Were all samples taken after the water sat undisturbed in pipes for at least 8 hours but no more than 48 hours?
9. ☐ YES ☐ NO	Were samples collected in pre-cleaned high density polyethylene (HDPE) 250 ml wide mouth single use rigid sample containers?
10. ☐ YES ☐ NO	Were all existing aerators, screens, and filters left in place prior to and during the sampling event?
11. ☐ YES ☐ NO	Were only cold water samples collected?
12. ☐ YES ☐ NO	Did no pre-stagnant flushing take place unless the outlet deviated from normal use and documented on flushing log?
13. ☐ YES ☐ NO	Was all point of use treatment on outlets, such as filters, documented?
14. ☐ YES ☐ NO	Did any result exceed the action level for lead (15 µg/L) or copper (1300 µg/L)?
15. ☐ YES ☐ NO ☐ N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) was use of all drinking water outlets immediately discontinued?
16. ☐ YES ☐ NO ☐ N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) was bottled water provided for drinking and food preparation?
17. ☐ YES ☐ NO ☐ N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) were signs posted to indicate that the outlets are not to be used for drinking or food preparation?

18. ☐ YES ☐ NO ☐ N/A	Did all drinking water outlets with a result that exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) have a follow-up flush sample conducted?
19. ☐ YES ☐ NO ☐ N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) was the local health office notified of results?
20. ☐ YES ☐ NO ☐ N/A	If any of the results exceeded the action level for lead (15 µg/L) or copper (1300 µg/L), was notification, including results and remediation measures, provided to the parent(s) of all children attending the center, the staff, and NJDCF?
21. ☐ YES ☐ NO ☐ N/A	Were any drinking water outlets or potable plumbing replaced or repaired as a remedy for an action level exceedance?
22. ☐ YES ☐ NO ☐ N/A Sample Date:	If any drinking water outlet or potable plumbing was replaced or repaired, were additional samples collected after installation?
23. ☐ YES ☐ NO ☐ N/A	Was any chemical treatment unit or process installed to remedy an action level exceedance (e.g., corrosion control treatment)?
24. ☐ YES ☐ NO ☐ N/A Sample Date:	If a chemical treatment unit or process was installed to remedy an action level exceedance (e.g., corrosion control treatment), were additional samples collected after the installation?
25. ☐ YES ☐ NO ☐ N/A	Was a mechanical process implemented to remedy an action level exceedance (e.g., flushing program)?
26. ☐ YES ☐ NO ☐ N/A	If a mechanical process was implemented to remedy an action level exceedance (e.g., flushing program), were additional samples collected after the implementation?
27. ☐ YES ☐ NO ☐ N/A	If no remedial action was taken, such as those indicated in 21 through 26 above, has the center implemented a written plan of action for use of bottled water for drinking and food preparation?

CERTIFICATION: By signing below, the **Sponsor or Sponsor Representative** certifies that all answers on this checklist are true and accurate:

Sponsor/Sponsor Representative: (PRINT)	
Signature:	
Signature Date:	

DRINKING WATER TESTING RESOURCES

Schools - Lead Sampling Information

<http://www.nj.gov/dep/watersupply/schools.htm>

Lead Sampling in Schools Technical Guidance FAQs

<http://www.nj.gov/dep/watersupply/pdf/leadfaq.pdf>

3Ts for Reducing Lead in Drinking Water: Testing

<https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-testing>

Quick Reference Guide Sampling For Lead in Drinking Water in Schools:

<http://www.nj.gov/dep/watersupply/pdf/quickref.pdf>

List of NJ Certified Laboratories:

<https://www13.state.nj.us/DataMiner/Search/SearchByCategory?isExternal=y&getCategory=y&catName=Certified+Laboratories>

Drinking Water Outlet Inventory Form:

http://www.nj.gov/dep/watersupply/doc/SP_Attachment%20C.docx

Sampling Water Use Certification:

http://www.nj.gov/dep/watersupply/doc/SP_Attachment%20F.docx

Filter Inventory Form:

http://www.nj.gov/dep/watersupply/doc/SP_Attachment%20D.docx

Results Letter Template:

<http://www.nj.gov/dep/watersupply/doc/resultsletter.doc>

State of New Jersey
Department of Children and Families
Office of Licensing

DRINKING WATER TESTING STATEMENT OF ASSURANCE

• PROGRAMS IN OPERATING PUBLIC SCHOOLS ARE NOT REQUIRED TO COMPLETE THIS FORM •

Name of Child Care Center:		License ID:
Site Address (Building # and Street): 330 Duncan Avenue		
Municipality:	County:	
Sponsor/Sponsor Representative:		Phone #: (800) 423-0766
Sponsor/Sponsor Representative Email: Gclare@mccabeenv.com		
Additional Contact Person:		Phone #:
Title:	Email:	

1. The center, as described above, has reviewed the MANUAL OF REQUIREMENTS FOR CHILD CARE CENTERS requiring testing for lead and copper in drinking water and provides assurance that the development and implementation of a testing program was completed in accordance with N.J.A.C. 3A:52-5.3(i)5i as evidenced by our completion of the attached Drinking Water Testing Checklist.
2. The center, as described above, provided all notifications of test results consistent with the requirements of this subchapter.
3. The center, as described above, will continue to fully implement the requirements of this subchapter, including the continuance of any actions taken in response to a lead or copper action level exceedance (e.g., continue to provide bottled water and/or maintain any remedial measure or treatment unit).

CERTIFICATION: By signing below, the **Sponsor or Sponsor Representative** certifies that all statements above are true and accurate:

Sponsor/Sponsor Representative: (PRINT)	
Signature:	
Signature Date:	

APPENDIX C

SAMPLE LOCATION DRAWING

