



464 Valley Brook Avenue, Lyndhurst NJ 07071
129 Sea Girt Avenue, Manasquan NJ 08736
Phone: (800) 423-0766 • Fax: (201) 438-1798
www.mccabeenv.com

LEAD & COPPER IN DRINKING WATER TESTING REPORT

Conducted for:

Greater Bergen Community Action
192 Main Street
Hackensack, New Jersey 07601

Conducted at:

Marion Gardens
57 Dales Avenue
Jersey City, New Jersey 07306

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: September 9, 2024

MES PROJECT NO.: 24-04997

Prepared by:

A handwritten signature in blue ink, appearing to read 'Kevin Brossok', is written over a light blue circular stamp.

Kevin Brossok
Environmental Scientist

Signed for the Company by:

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello', is written over a light blue circular stamp.

John H. Chiaviello
Vice President

TABLE OF CONTENTS

	Page
1.0 INTRODUCTION	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS	2
5.0 DISCUSSION AND CONCLUSION	2

APPENDIX A

Laboratory Certificates of Analysis
&
Sample Chain of Custody Forms

APPENDIX B

Sampling Plan Attachments

1.0 INTRODUCTION

McCabe Environmental Services, L.L.C. (McCabe) was retained by Greater Bergen Community Action (Client) to conduct testing of lead and copper in drinking water at 57 Dales Avenue, Jersey City, New Jersey.

The project information is as follows:

<u>Client Name:</u>	Greater Bergen Community Action
<u>Contact Person:</u>	Mr. Raul Torres
<u>Project Name:</u>	Lead and Copper in Drinking Water Testing
<u>Project Location:</u>	57 Dales Avenue Jersey City, New Jersey 07306
<u>Date(s) of Service:</u>	August 23, 2024
<u>McCabe Personnel:</u>	Kevin Brossok

2.0 SCOPE OF WORK

Drinking water testing was performed at Marion Gardens at 57 Dales Avenue, Jersey City, New Jersey on August 23, 2024. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead and copper concentrations. Samples were collected from various potential drinking water outlets located throughout the building.

3.0 PROCEDURES

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) and 1300 ppb for copper collected for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

4.0 TABLE OF SAMPLE RESULTS

The following table presents all sample results in order of sample identification:

Sample ID	Sample Location	Lead Result (ppb)	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)	Copper Result (ppb)	Exceeds (MCL 1300 ppb)
DW-01	Room 103A Kids Sink	< 0.5	Pass	Pass	202	Pass
DW-02	Room 103A Food Prep Sink to Left	0.8	Pass	Pass	255	Pass
DW-03	Kitchen Main Sink	< 0.5	Pass	Pass	139	Pass
DW-04	Kitchen Handwashing Sink	0.7	Pass	Pass	392	Pass
DW-05	117B Classroom Sink at Counter	< 0.5	Pass	Pass	269	Pass
DW-06	117A Bathroom Sink	< 0.5	Pass	Pass	268	Pass
DW-07	115A Bathroom Sink	< 0.5	Pass	Pass	184	Pass
DW-08	116A Bathroom Sink	< 0.5	Pass	Pass	188	Pass
DW-09	Janitor Closet Sink (114A)	< 0.5	Pass	Pass	65	Pass
DW-10	Room 103A – Adult Sink	< 0.5	Pass	Pass	220	Pass

5.0 DISCUSSION AND CONCLUSION

A total of ten (10) samples were collected from Marion Gardens. All samples were found to be less than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb, as well as the EPA Lead and Copper Rule standard of 15 ppb. All samples were also found to meet the EPA standard of 1300 parts per billion (ppb) for copper set by the EPA Lead and Copper rule.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building’s plumbing is not having an adverse impact on water quality.

APPENDIX A

**LABORATORY CERTIFICATES OF ANALYSIS
&
SAMPLE CHAIN OF CUSTODY FORMS**



Tuesday, September 03, 2024

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
SDG ID: GCR48309
Sample ID#s: CR48309 - CR48318

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

September 03, 2024

SDG I.D.: GCR48309

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION

Client Id	Lab Id	Matrix
DW-01	CR48309	DRINKING WATER
DW-02	CR48310	DRINKING WATER
DW-03	CR48311	DRINKING WATER
DW-04	CR48312	DRINKING WATER
DW-05	CR48313	DRINKING WATER
DW-06	CR48314	DRINKING WATER
DW-07	CR48315	DRINKING WATER
DW-08	CR48316	DRINKING WATER
DW-09	CR48317	DRINKING WATER
DW-10	CR48318	DRINKING WATER



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report
 September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

7:50
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48309

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	202	25	10	ppb	1300		1000	08/29/24	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

7:52
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48310

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	255	25	10	ppb	1300		1000	08/29/24	CPP	E200.8
Lead	0.8	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report
 September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

7:54
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48311

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	139	13	5	ppb	1300		1000	08/29/24	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report
 September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

7:56
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48312

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	392	25	10	ppb	1300		1000	08/29/24	CPP	E200.8
Lead	0.7	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

7:59
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48313

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	269	25	10	ppb	1300		1000	08/29/24	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

8:02
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48314

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	268	25	10	ppb	1300		1000	08/29/24	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

8:04
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48315

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	184	13	5	ppb	1300		1000	08/29/24	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report
 September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

8:07
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48316

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	188	13	5	ppb	1300		1000	08/29/24	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

8:10
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48317

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	65	5	2	ppb	1300		1000	08/29/24	AL1	E200.8
Lead	< 0.5	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

September 03, 2024

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/24
 08/23/24

Time

8:12
 18:02

Laboratory Data

SDG ID: GCR48309
 Phoenix ID: CR48318

Project ID: 24-04997 GREATER BERGEN COMMUNITY ACTION
 Client ID: DW-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	220	13	5	ppb	1300		1000	08/29/24	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			08/29/24	AL1	E200.8
Total Metal Digestion (MS)	Completed							08/28/24	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2024

Reviewed and Released by: Anil Makol, Project Manager

Analysis Report - Summary

September 03, 2024

Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCR48309




Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 24-04997 Greater Bergen Community Action								
CR48309	DW-01	08/23/24	Copper	202	25	ppb	08/29/24	E200.8
CR48309	DW-01	08/23/24	Lead	< 0.5	0.5	ppb	08/29/24	E200.8
CR48310	DW-02	08/23/24	Copper	255	25	ppb	08/29/24	E200.8
CR48310	DW-02	08/23/24	Lead	0.8	0.5	ppb	08/29/24	E200.8
CR48311	DW-03	08/23/24	Copper	139	13	ppb	08/29/24	E200.8
CR48311	DW-03	08/23/24	Lead	< 0.5	0.5	ppb	08/29/24	E200.8
CR48312	DW-04	08/23/24	Copper	392	25	ppb	08/29/24	E200.8
CR48312	DW-04	08/23/24	Lead	0.7	0.5	ppb	08/29/24	E200.8
CR48313	DW-05	08/23/24	Copper	269	25	ppb	08/29/24	E200.8
CR48313	DW-05	08/23/24	Lead	< 0.5	0.5	ppb	08/29/24	E200.8
CR48314	DW-06	08/23/24	Copper	268	25	ppb	08/29/24	E200.8
CR48314	DW-06	08/23/24	Lead	< 0.5	0.5	ppb	08/29/24	E200.8
CR48315	DW-07	08/23/24	Copper	184	13	ppb	08/29/24	E200.8
CR48315	DW-07	08/23/24	Lead	< 0.5	0.5	ppb	08/29/24	E200.8
CR48316	DW-08	08/23/24	Copper	188	13	ppb	08/29/24	E200.8
CR48316	DW-08	08/23/24	Lead	< 0.5	0.5	ppb	08/29/24	E200.8
CR48317	DW-09	08/23/24	Copper	65	5	ppb	08/29/24	E200.8
CR48317	DW-09	08/23/24	Lead	< 0.5	0.5	ppb	08/29/24	E200.8
CR48318	DW-10	08/23/24	Copper	220	13	ppb	08/29/24	E200.8
CR48318	DW-10	08/23/24	Lead	< 0.5	0.5	ppb	08/29/24	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
--------	-----------	-------------	-----------	--------	----	-------	------------------	-----------

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit



Phyllis Shiller
 Laboratory Director
 September 03, 2024



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



QA/QC Report

September 03, 2024

QA/QC Data

SDG I.D.: GCR48309

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 746749 (mg/L), QC Sample No: CR48309 2X (CR48309, CR48310, CR48311, CR48312, CR48313, CR48314, CR48315, CR48316, CR48317, CR48318)

ICP MS Metals - Aqueous


Copper	BRL	0.005	0.202	0.194	4.00	107					NC	85 - 115	20
Lead	BRL	0.0005	<0.0005	<0.0005	NC	105					98.2	85 - 115	20

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 70-130%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


 Phyllis Shiller, Laboratory Director
 September 03, 2024

Tuesday, September 03, 2024

Criteria: NJ: DW

State: NJ

Sample Criteria Exceedances Report

GCR48309 - MCCABE

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

September 03, 2024





SDG I.D.: GCR48309

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

1.8 water

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNDDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD & COPPER in DRINKING WATER
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action		SITE ADDRESS: 57 Dales Avenue, Jersey City NJ 07306		
FIELD INSPECTOR'S NAME: Kevin Brossok		TURNAROUND TIME REQUESTED: 2 Weeks		
MES PROJECT #: 24-04997	SAMPLE DATE: 8/23/2024			
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	DW-01	Room 103A Kids Sink	7:50	COPPER - 200.7 LEAD - 200.8
DW	DW-02	Room 103A Foodprep sink to left	7:52	COPPER - 200.7 LEAD - 200.8
DW	DW-03	Kitchen - main sink	7:54	COPPER - 200.7 LEAD - 200.8
DW	DW-04	Kitchen - handwashing sink	7:56	COPPER - 200.7 LEAD - 200.8
DW	DW-05	117B classroom sink at counter	7:59	COPPER - 200.7 LEAD - 200.8
DW	DW-06	117A Bathroom sink	8:02	COPPER - 200.7 LEAD - 200.8
DW	DW-07	115A Bathroom sink	8:04	COPPER - 200.7 LEAD - 200.8
DW	DW-08	116A Bathroom sink	8:07	COPPER - 200.7 LEAD - 200.8
DW	DW-09	Janitors closet sink (114A)	8:10	COPPER - 200.7 LEAD - 200.8
DW	DW-10	Room 103A - Food Prep Sink	8:12	COPPER - 200.7 LEAD - 200.8
Relinquished by (Print) Kevin Brossok		Date: 8/23/24	Time: 18:00	
Signature: 		Received by: (Print) Omar Hassan	Signature: 	Date: 8/23/24
Relinquished by (Print) Omar Hassan		Date: 8/23/24	Time: 18:00	
Signature: 		Received by: (Print)	Signature: 	Date:
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories				

APPENDIX B

**SAMPLING PLAN
ATTACHMENTS**

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Marion Gardens	08/05/2021	Phoenix	

Attachment B – Plumbing Profile

Note: Complete for each school. For additional information see the USEPA publication, “The 3Ts for Reducing Lead in Drinking Water in Schools”

Name of School: Marion Gardens Grade Levels: Pre-K

Address: 57 Dales Avenue, Jersey City, New Jersey

Individual school project officer Signature: Raul Torres

Date: 08/23/2024

Questions	Answers	
Background Information		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	1943	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Yes	
3. Where are the most recent plumbing repairs and replacements?	Location: Common bathrooms, kitchen, early head start and head start classroom and laundry room.	Description: H/C for toilets and sinks
4. With what materials is the service connection (the pipe that carries water to the school from the public water system’s main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Copper Location: Existing Electrical Room	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N Type:	Location:

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	No
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N All new fixtures installed
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N New facility, new fixtures and plumbing Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> • Name of contaminant(s) • Concentrations found • pH level Is testing done regularly at the building?	N/A
11. Other plumbing background questions include: <ul style="list-style-type: none"> • Are blueprints of the building available? • Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”? Are renovations planned for any of the plumbing system?	Yes Unknown, all new plumbing fixtures and a portion of the interior piping Unknown

Questions	Answers	
<p>Walk-Through <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i></p>		
1. Confirm the material of Service Line visually.	Copper	
2. Confirm the presence of POE or POU treatment.	Basement	
<p>3. What are the potable water pipes made of in your facility?</p> <ul style="list-style-type: none"> • Lead • Plastic • Galvanized Metal • Cast Iron • Copper • Other <p>Note the water flow through the building and the areas that receive water first, and which areas receive water last.</p>	N/A	
<p>4. Are electrical wires grounded to Water Pipes? Note location(s).</p>	<input checked="" type="radio"/> Y / N	<p>Location: Basement & Mechanical Room</p>
<p>5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.</p>	<p>Complete in “Brass” Column in Attachment C- Water Outlet Inventory.</p> <p>Yes- Presumed</p>	
<p>6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.</p>	<p>Complete in Attachment C-Water Outlet Inventory.</p> <p>Early Head Start classroom, Head Start Classroom & Kitchen</p>	

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N</p> <p>Type</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p> <p>Unknown. New Facility, New Fixtures and Plumbing</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p style="text-align: right;">Permanently</p> <p style="text-align: right;">Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

Attachment C – Drinking Water Outlet Inventory

Name of School: 57 Dales Avenue, Jersey City, New Jersey

Grade Levels: Pre-K

Year School Constructed: 1943

Renovated/Additions: None

Individual school project officer Name/Signature: Raul Torres

Date Completed: 08/23/2024

# ¹	Type	Location	Code	Operational ² (Y/N)	Signs of Corrosion ³ (Y/N)	Filter ⁴ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Sink	Room 103A – Kid’s Sink	01	Y	N	N	N	Y	N	N	NA	NA	
02	Sink	Room 103A – Food Prep Sink to Left	02	Y	N	N	N	Y	N	N	NA	NA	
03	Sink	Kitchen Sink – Main Sink	03	Y	N	N	N	Y	N	N	NA	NA	
04	Sink	Kitchen – Handwashing Sink	04	Y	N	N	N	Y	N	N	NA	NA	
05	Sink	117B Classroom Sink at Counter	05	Y	N	N	N	Y	N	N	NA	NA	
06	Sink	117A Bathroom Sink	06	Y	N	N	N	Y	N	N	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.

07	Sink	115A Bathroom Sink	07	Y	N	N	N	Y	N	N	NA	NA	
08	Sink	116A Bathroom Sink	08	Y	N	N	N	Y	N	N	NA	NA	
09	Sink	Janitor's Closet Sink (114A)	09	Y	N	N	N	Y	N	N	NA	NA	
10	Sink	Room 103A – Adult Sink	10	Y	N	N	N	Y	N	N	NA	NA	

Attachment D - Filter Inventory

Name of School: Marion Gardens

Grade Levels: Pre-K

Address: 57 Dales Avenue, Jersey City, New Jersey

Individual School Project Officer Signature: Raul Torres

Date: 08/23/2024

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
Room 103A – Kid’s Sink	NA	Sink	NA	NA	NA
Room 103A – Food Prep Sink to Left	NA	Sink	NA	NA	NA
Kitchen Sink – Main Sink	NA	Sink	NA	NA	NA
Kitchen – Handwashing Sink	NA	Sink	NA	NA	NA
117B Classroom Sink at Counter	NA	Sink	NA	NA	NA
117A Bathroom Sink	NA	Sink	NA	NA	NA
115A Bathroom Sink	NA	Sink	NA	NA	NA
116A Bathroom Sink	NA	Sink	NA	NA	NA
Janitor’s Closet Sink (114A)	NA	Sink	NA	NA	NA
Room 103A – Adult Sink	NA	Sink	NA	NA	NA

Attachment E – Flushing LogName of School: Marion GardensAddress: 57 Dales Avenue, Jersey City, New JerseyGrade Levels: Pre-KIndividual School Project Officer: Raul TorresDate: 08/23/2024

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Room 103A – Kid’s Sink	01	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling
Room 103A Food Prep Sink to Left	02	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling
Kitchen Sink – Main Sink	03	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling
Kitchen – Handwashing Sink	04	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling
117B Classroom Sink at Counter	05	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling
117A Bathroom Sink	06	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling
115A Bathroom Sink	07	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling
116A Bathroom Sink	08	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling
Janitor’s Closet Sink (114A)	09	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling
Room 103A – Adult Sink	10	August 22, 2024	3:00 pm	2-3 minutes	Water Sampling

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE MARION GARDENS DISTRICT REPRESENTATIVE:		
School Name: Marion Gardens		
Sample collection address:	57 Dales Avenue, Jersey City, New Jersey	
Water was last used:	Time: 3:00 pm	Date: August 22, 2024
Sample commencement:	Time: 7:50 am	Date: August 23, 2024
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Raul Torres	09/09/2024	
Signature	Date	

DRINKING WATER TESTING CHECKLIST

Note: This form is for child care centers that are supplied water by a community water system.

•PROGRAMS IN OPERATING PUBLIC SCHOOLS ARE NOT REQUIRED TO COMPLETE THIS FORM•

CHILD CARE CENTER INFORMATION


Name of Child Care Center: Marion Gardens		License ID:	
Site Address of Center:	Building # and Street: 57 Dales Avenue	Municipality: Jersey City	County: Hudson
Sponsor/Sponsor Representative: Greater Bergen Community		Phone Number: 201-968-0200	Email: raul.torres@GreaterBergen.org

CERTIFICATION OF COMPLIANCE WITH LEAD & COPPER SAMPLING AT THE ABOVE CHILD CARE CENTER

Sampling Date(s):	
1. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Does the center have a signed contract with a New Jersey Certified Drinking Water Laboratory for lead & copper analysis?
2. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Is there an onsite water outlet assessment in accordance with technical guidance?
3. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	Is there a floor plan in accordance with technical guidance?
4. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO Sample Date: 8-23-24	Were all the drinking water outlets in the center where a child or staff has or may have access (including food preparation and outside drinking water outlets) sampled?
5. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO Sample Date: 8-23-24	Were at least 50% of all indoor water faucets utilized by the center sampled?
6. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Does the child care center have the chain of custody and analytical reports for all drinking water outlets sampled? Please attach copies.
7. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Was all the drinking water outlets sampled in the sequence determined by the floor plan beginning with the outlet closest to the point of entry?
8. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Were all samples taken after the water sat undisturbed in pipes for at least 8 hours but no more than 48 hours?
9. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Were samples collected in pre-cleaned high density polyethylene (HDPE) 250 ml wide mouth single use rigid sample containers?
10. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Were all existing aerators, screens, and filters left in place prior to and during the sampling event?
11. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Were only cold water samples collected?
12. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Did no pre-stagnant flushing take place unless the outlet deviated from normal use and documented on flushing log?
13. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Was all point of use treatment on outlets, such as filters, documented?
14. <input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO	Did any result exceed the action level for lead (15 µg/L) or copper (1300 µg/L)?
15. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) was use of all drinking water outlets immediately discontinued?
16. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) was bottled water provided for drinking and food preparation?
17. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) were signs posted to indicate that the outlets are not to be used for drinking or food preparation?

18. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	Did all drinking water outlets with a result that exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) have a follow-up flush sample conducted?
19. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) was the local health office notified of results?
20. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	If any of the results exceeded the action level for lead (15 µg/L) or copper (1300 µg/L), was notification, including results and remediation measures, provided to the parent(s) of all children attending the center, the staff, and NJDCF?
21. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	Were any drinking water outlets or potable plumbing replaced or repaired as a remedy for an action level exceedance?
22. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A Sample Date:	If any drinking water outlet or potable plumbing was replaced or repaired, were additional samples collected after installation?
23. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	Was any chemical treatment unit or process installed to remedy an action level exceedance (e.g., corrosion control treatment)?
24. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A Sample Date:	If a chemical treatment unit or process was installed to remedy an action level exceedance (e.g., corrosion control treatment), were additional samples collected after the installation?
25. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	Was a mechanical process implemented to remedy an action level exceedance (e.g., flushing program)?
26. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	If a mechanical process was implemented to remedy an action level exceedance (e.g., flushing program), were additional samples collected after the implementation?
27. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	If no remedial action was taken, such as those indicated in 21 through 26 above, has the center implemented a written plan of action for use of bottled water for drinking and food preparation?

CERTIFICATION: By signing below, the **Sponsor or Sponsor Representative** certifies that all answers on this checklist are true and accurate:

Sponsor/Sponsor Representative: (PRINT)	BRANDON SOTO
Signature:	
Signature Date:	9-9-24

DRINKING WATER TESTING RESOURCES

Schools - Lead Sampling Information

<http://www.nj.gov/dep/watersupply/schools.htm>

Lead Sampling in Schools Technical Guidance FAQs

<http://www.nj.gov/dep/watersupply/pdf/leadfaq.pdf>

3Ts for Reducing Lead in Drinking Water: Testing

<https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-testing>

Quick Reference Guide Sampling For Lead in Drinking Water in Schools:

<http://www.nj.gov/dep/watersupply/pdf/quickref.pdf>

List of NJ Certified Laboratories:

<https://www13.state.nj.us/DataMiner/Search/SearchByCategory?isExternal=y&getCategory=y&catName=Certified+Laboratories>

Drinking Water Outlet Inventory Form:

http://www.nj.gov/dep/watersupply/doc/SP_Attachment%20C.docx

Sampling Water Use Certification:

http://www.nj.gov/dep/watersupply/doc/SP_Attachment%20F.docx

Filter Inventory Form:

http://www.nj.gov/dep/watersupply/doc/SP_Attachment%20D.docx

Results Letter Template:

<http://www.nj.gov/dep/watersupply/doc/resultsletter.doc>