



LEAD & COPPER IN DRINKING WATER TESTING REPORT

Conducted for:

Greater Bergen Community Action
392 Main Street
Hackensack, New Jersey 07601

Conducted at:

Lincoln Park
330 Duncan Avenue
Jersey City, New Jersey 07307

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: June 10, 2019

MES PROJECT NO.: 19-03619

Prepared by:

**Gary Clare
Environmental Scientist**

Signed for the Company by:

**John H. Chiaviello
Vice President**

TABLE OF CONTENTS

	Page
1.0 INTRODUCTION	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS	2-5
5.0 DISCUSSION AND CONCLUSION	5

APPENDIX A

Laboratory Certificates of Analysis
&
Sample Chain of Custody Forms

APPENDIX B

Sampling Plan Attachments

1.0 INTRODUCTION

McCabe Environmental Services, L.L.C. (McCabe) was retained by Greater Bergen Community Action to conduct lead & copper in drinking water testing at the Greater Bergen Community Actions facility located at 330 Duncan Avenue, Jersey City, New Jersey 07307.

The project information is as follows:

Client Name: Greater Bergen Community Action
Contact Person: Mr. Jeff Martin

Project Name: Lead & Copper in Drinking Water
Project Location: 330 Duncan Avenue
Jersey City, New Jersey 07307

Date(s) of Service: April 6, 2019

McCabe Personnel: Gary Clare

2.0 SCOPE OF WORK

Drinking water testing was performed at the Greater Bergen Community Actions facility located at 330 Duncan Avenue, Jersey City, New Jersey 07307 on April 6, 2019. The purpose of the testing was to determine if the building's plumbing was having an adverse impact on water quality, specifically with regard to lead and copper concentrations. Samples were collected from various potential drinking water outlets located throughout the building.

3.0 PROCEDURES

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. All samples were collected into 250 mL sterile bottles containing a nitric acid preservative, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead and copper in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) and 1300 ppb for copper collected in a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample for lead. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

4.0 TABLES OF SAMPLE RESULTS

The following table presents all lead and copper sample results in order of sample identification:

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
LP-01	Classroom 101 Food Prep Sink	0.7	Pass	Pass	8	Pass
LP-02	Classroom 101	< 0.5	Pass	Pass	36	Pass
LP-03	Classroom 101/102 Bathroom Sink	< 0.5	Pass	Pass	12	Pass
LP-04	Classroom 102 Food Prep Sink	< 0.5	Pass	Pass	8	Pass
LP-05	Classroom 103 Food Prep Sink	< 0.5	Pass	Pass	7	Pass
LP-06	Classroom 103	< 0.5	Pass	Pass	24	Pass
LP-07	Classroom 103 Bathroom Sink	0.6	Pass	Pass	10	Pass
LP-08	Classroom 104 Food Prep Sink	< 0.5	Pass	Pass	9	Pass
LP-09	Classroom 104	< 0.5	Pass	Pass	41	Pass
LP-010	Classroom 104/105 Bathroom Sink	< 0.5	Pass	Pass	7	Pass
LP-11	Classroom 105 Food Prep Sink	0.7	Pass	Pass	13	Pass
LP-12	Classroom 105	< 0.5	Pass	Pass	8	Pass
LP-13	Classroom 106 Food Prep Sink	< 0.5	Pass	Pass	9	Pass
LP-14	Classroom 106	< 0.5	Pass	Pass	33	Pass

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
LP-15	Classroom 106/107 Bathroom Sink	< 0.5	Pass	Pass	7	Pass
LP-16	Classroom 107 Food Prep Sink	< 0.5	Pass	Pass	12	Pass
LP-17	Classroom 107	< 0.5	Pass	Pass	58	Pass
LP-18	2 nd Floor Kitchen Sink (Left)	< 0.5	Pass	Pass	15	Pass
LP-19	Classroom 202	< 0.5	Pass	Pass	14	Pass
LP-20	Classroom 202	< 0.5	Pass	Pass	26	Pass
LP-21	Classroom 202 Bathroom Sink	< 0.5	Pass	Pass	6	Pass
LP-22	Classroom 203	< 0.5	Pass	Pass	13	Pass
LP-23	Classroom 203	0.8	Pass	Pass	41	Pass
LP-24	Classroom 203 Bathroom Sink	< 0.5	Pass	Pass	8	Pass
LP-25	Classroom 204	< 0.5	Pass	Pass	8	Pass
LP-26	Classroom 204	< 0.5	Pass	Pass	11	Pass
LP-27	Classroom 204 Bathroom Sink	< 0.5	Pass	Pass	8	Pass
LP-28	Main Office 205 Staff Bathroom Sink	< 0.5	Pass	Pass	5	Pass
LP-29	Main Office Room 208 Bathroom Sink	11.6	Pass	Pass	108	Pass
LP-30	Teacher Workroom 212 Sink	0.5	Pass	Pass	14	Pass

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
LP-31	Teacher Workroom 212 Bathroom Sink	1.4	Pass	Pass	8	Pass
LP-32	Room 210	< 0.5	Pass	Pass	34	Pass
LP-33	Room 210 Bathroom Sink	< 0.5	Pass	Pass	< 5	Pass
LP-34	Classroom 201 Sink	< 0.5	Pass	Pass	10	Pass
LP-35	Classroom 201	< 0.5	Pass	Pass	14	Pass
LP-36	Classroom 201 Bathroom Sink	< 0.5	Pass	Pass	6	Pass
LP-37	2 nd Floor Kitchen Sink (Right)	2.5	Pass	Pass	19	Pass
LP-38	2nd Floor Janitor Closet SJ1 Sink	24.8	Fail	Fail	63	Pass
LP-39	Classroom 101 Porcelain Sink	< 0.5	Pass	Pass	6	Pass
LP-40	Classroom 102 Porcelain Sink	< 0.5	Pass	Pass	7	Pass
LP-41	Classroom 103 Porcelain Sink	< 0.5	Pass	Pass	6	Pass
LP-42	Classroom 104 Porcelain Sink	< 0.5	Pass	Pass	6	Pass
LP-43	Classroom 105 Porcelain Sink	< 0.5	Pass	Pass	6	Pass
LP-44	Classroom 106 Porcelain Sink	< 0.5	Pass	Pass	8	Pass
LP-45	Classroom 107 Porcelain Sink	0.5	Pass	Pass	10	Pass

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
LP-46	Classroom 102	< 0.5	Pass	Pass	21	Pass
LP-47	2 nd Floor Kitchen Handwashing Sink	6.2	Pass	Pass	50	Pass
LP-48	2 nd Floor Nurses Office Sink	3.1	Pass	Pass	69	Pass
LP-49	1 st Floor Janitors Closet FJ1- 2 minute flush	< 0.5	Pass	Pass	5	Pass

5.0 DISCUSSION AND CONCLUSION

A total of forty-nine (49) samples were collected from Lincoln Park, 330 Duncan Avenue, Jersey City, New Jersey 07307. One sample, LP-38 was greater than the EPA Lead Rule Standard only. McCabe recommends to discontinue the use of this location. All other samples were found to be less than the EPA Lead and Copper Rule standard of 15 ppb & 20 ppb for lead and 1300 ppb for copper.

The following outlets were found to be above EPA Lead and Copper Rule standard of 15 ppb and also greater than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb:

- 2nd Floor Janitor Closet SJI Sink

The elevated lead concentration for the sample listed above was observed from “first draw” sample. Often, “first draw” samples have higher concentrations because compounds leach from the surrounding pipe as water sits stagnant for a duration of time. The lead concentration found at this locations indicates that there are potentially lead pipes within the school, brass faucets or fittings, and/or solder which may contain lead.

McCabe recommends discontinued usage of the outlets which resulted in failed results until additional samples can be collected and analyzed and a permanent solution can be recommended.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building’s plumbing is not having an adverse impact on water quality.

APPENDIX A

**LABORATORY CERTIFICATES OF ANALYSIS
&
SAMPLE CHAIN OF CUSTODY FORMS**



Friday, April 12, 2019

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: GREATER BERGEN LINCOLN PARK
SDG ID: GCC90745
Sample ID#s: CC90745 - CC90793

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Phyllis Shiller".

Phyllis Shiller

Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
UT Lab Registration #CT00007
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

April 12, 2019

SDG I.D.: GCC90745

Project ID: GREATER BERGEN LINCOLN PARK

Client Id	Lab Id	Matrix
LP-01	CC90745	DRINKING WATER
LP-02	CC90746	DRINKING WATER
LP-03	CC90747	DRINKING WATER
LP-04	CC90748	DRINKING WATER
LP-05	CC90749	DRINKING WATER
LP-06	CC90750	DRINKING WATER
LP-07	CC90751	DRINKING WATER
LP-08	CC90752	DRINKING WATER
LP-09	CC90753	DRINKING WATER
LP-10	CC90754	DRINKING WATER
LP-11	CC90755	DRINKING WATER
LP-12	CC90756	DRINKING WATER
LP-13	CC90757	DRINKING WATER
LP-14	CC90758	DRINKING WATER
LP-15	CC90759	DRINKING WATER
LP-16	CC90760	DRINKING WATER
LP-17	CC90761	DRINKING WATER
LP-18	CC90762	DRINKING WATER
LP-19	CC90763	DRINKING WATER
LP-20	CC90764	DRINKING WATER
LP-21	CC90765	DRINKING WATER
LP-22	CC90766	DRINKING WATER
LP-23	CC90767	DRINKING WATER
LP-24	CC90768	DRINKING WATER
LP-25	CC90769	DRINKING WATER
LP-26	CC90770	DRINKING WATER
LP-27	CC90771	DRINKING WATER
LP-28	CC90772	DRINKING WATER
LP-29	CC90773	DRINKING WATER
LP-30	CC90774	DRINKING WATER



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

April 12, 2019

SDG I.D.: GCC90745

Project ID: GREATER BERGEN LINCOLN PARK

Client Id	Lab Id	Matrix
LP-31	CC90775	DRINKING WATER
LP-32	CC90776	DRINKING WATER
LP-33	CC90777	DRINKING WATER
LP-34	CC90778	DRINKING WATER
LP-35	CC90779	DRINKING WATER
LP-36	CC90780	DRINKING WATER
LP-37	CC90781	DRINKING WATER
LP-38	CC90782	DRINKING WATER
LP-39	CC90783	DRINKING WATER
LP-40	CC90784	DRINKING WATER
LP-41	CC90785	DRINKING WATER
LP-42	CC90786	DRINKING WATER
LP-43	CC90787	DRINKING WATER
LP-44	CC90788	DRINKING WATER
LP-45	CC90789	DRINKING WATER
LP-46	CC90790	DRINKING WATER
LP-47	CC90791	DRINKING WATER
LP-48	CC90792	DRINKING WATER
LP-49	CC90793	DRINKING WATER



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

8:45
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90745

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	8	5	2	ppb	1300			04/09/19	CPP	E200.8
Lead	0.7	0.5	2	ppb	15			04/09/19	CPP	E200.8
Total Metal Digestion	Completed							04/08/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

8:47
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90746

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	36	5	2	ppb	1300			04/09/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/09/19	CPP	E200.8
Total Metal Digestion	Completed							04/08/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

8:50
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90747

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	12	5	2	ppb	1300			04/09/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/09/19	CPP	E200.8
Total Metal Digestion	Completed							04/08/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

8:52
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90748

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	8	5	2	ppb	1300			04/09/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/09/19	CPP	E200.8
Total Metal Digestion	Completed							04/08/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

8:55
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90749

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	7	5	2	ppb	1300			04/09/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/09/19	CPP	E200.8
Total Metal Digestion	Completed							04/08/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

8:59
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90750

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	24	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

8:59
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90751

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	10	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	0.6	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:02
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90752

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	9	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:04
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90753

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	41	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:07
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90754

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	7	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:15
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90755

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	13	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	0.7	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:17
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90756

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	8	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:19
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90757

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	9	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:21
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90758

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	33	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:23
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90759

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	7	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:26
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90760

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	12	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:29
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90761

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	58	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:35
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90762

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	15	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:40
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90763

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	14	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:45
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90764

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	26	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:50
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90765

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	6	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:52
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90766

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	13	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:54
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90767

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	41	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	0.8	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:57
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90768

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-24

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	8	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

9:59
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90769

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	8	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:02
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90770

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-26

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	11	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:04
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90771

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-27

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	8	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:05
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90772

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-28

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:08
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90773

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-29

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	108	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	11.6	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:12
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90774

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-30

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	14	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:18
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90775

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-31

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	8	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	1.4	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:23
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90776

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-32

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	34	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:25
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90777

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-33

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	< 5	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:29
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90778

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-34

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	10	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:32
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90779

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-35

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	14	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:36
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90780

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-36

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	6	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:42
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90781

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-37

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	19	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	2.5	0.5	2	ppb	15			04/10/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:48
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90782

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-38

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	63	5	2	ppb	1300			04/10/19	CPP	E200.8
Lead	24.8	0.5	2	ppb	15			04/10/19	CPP	E200.8
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:52
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90783

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-39

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	6	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

10:56
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90784

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-40

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	7	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

11:00
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90785

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-41

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	6	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/09/19	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

11:08
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90786

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-42

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	6	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/10/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

11:09
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90787

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-43

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	6	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/10/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

11:13
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90788

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-44

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	8	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/10/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

11:16
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90789

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-45

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	10	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	0.5	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/10/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

11:20
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90790

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-46

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	21	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/10/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

11:24
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90791

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-47

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	50	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	6.2	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/10/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

11:27
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90792

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-48

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	69	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	3.1	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/10/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

April 12, 2019

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE
Rush Request: Standard
P.O.#: 19-03619

Custody Information

Collected by: GC
Received by: CP
Analyzed by: see "By" below

Date

04/06/19
04/08/19

Time

11:34
17:10

Laboratory Data

SDG ID: GCC90745
Phoenix ID: CC90793

Project ID: GREATER BERGEN LINCOLN PARK
Client ID: LP-49

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	5	5	2	ppb	1300			04/11/19	CPP	E200.8
Lead	< 0.5	0.5	2	ppb	15			04/11/19	CPP	E200.8
Total Metal Digestion	Completed							04/10/19	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

April 12, 2019

Reviewed and Released by: Rashmi Makol, Project Manager

Analysis Report - Summary

April 12, 2019

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCC90745



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: Greater Bergen Lincoln Park								
CC90745	LP-01	04/06/19	Copper	8	5	ppb	04/09/19	E200.8
CC90745	LP-01	04/06/19	Lead	0.7	0.5	ppb	04/09/19	E200.8
CC90746	LP-02	04/06/19	Copper	36	5	ppb	04/09/19	E200.8
CC90746	LP-02	04/06/19	Lead	< 0.5	0.5	ppb	04/09/19	E200.8
CC90747	LP-03	04/06/19	Copper	12	5	ppb	04/09/19	E200.8
CC90747	LP-03	04/06/19	Lead	< 0.5	0.5	ppb	04/09/19	E200.8
CC90748	LP-04	04/06/19	Copper	8	5	ppb	04/09/19	E200.8
CC90748	LP-04	04/06/19	Lead	< 0.5	0.5	ppb	04/09/19	E200.8
CC90749	LP-05	04/06/19	Copper	7	5	ppb	04/09/19	E200.8
CC90749	LP-05	04/06/19	Lead	< 0.5	0.5	ppb	04/09/19	E200.8
CC90750	LP-06	04/06/19	Copper	24	5	ppb	04/10/19	E200.8
CC90750	LP-06	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90751	LP-07	04/06/19	Copper	10	5	ppb	04/10/19	E200.8
CC90751	LP-07	04/06/19	Lead	0.6	0.5	ppb	04/10/19	E200.8
CC90752	LP-08	04/06/19	Copper	9	5	ppb	04/10/19	E200.8
CC90752	LP-08	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90753	LP-09	04/06/19	Copper	41	5	ppb	04/10/19	E200.8
CC90753	LP-09	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90754	LP-10	04/06/19	Copper	7	5	ppb	04/10/19	E200.8
CC90754	LP-10	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90755	LP-11	04/06/19	Copper	13	5	ppb	04/10/19	E200.8
CC90755	LP-11	04/06/19	Lead	0.7	0.5	ppb	04/10/19	E200.8
CC90756	LP-12	04/06/19	Copper	8	5	ppb	04/10/19	E200.8
CC90756	LP-12	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90757	LP-13	04/06/19	Copper	9	5	ppb	04/10/19	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CC90757	LP-13	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90758	LP-14	04/06/19	Copper	33	5	ppb	04/10/19	E200.8
CC90758	LP-14	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90759	LP-15	04/06/19	Copper	7	5	ppb	04/10/19	E200.8
CC90759	LP-15	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90760	LP-16	04/06/19	Copper	12	5	ppb	04/10/19	E200.8
CC90760	LP-16	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90761	LP-17	04/06/19	Copper	58	5	ppb	04/10/19	E200.8
CC90761	LP-17	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90762	LP-18	04/06/19	Copper	15	5	ppb	04/10/19	E200.8
CC90762	LP-18	04/06/19	Lead	0.5	0.5	ppb	04/10/19	E200.8
CC90763	LP-19	04/06/19	Copper	14	5	ppb	04/10/19	E200.8
CC90763	LP-19	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90764	LP-20	04/06/19	Copper	26	5	ppb	04/10/19	E200.8
CC90764	LP-20	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90765	LP-21	04/06/19	Copper	6	5	ppb	04/10/19	E200.8
CC90765	LP-21	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90766	LP-22	04/06/19	Copper	13	5	ppb	04/10/19	E200.8
CC90766	LP-22	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90767	LP-23	04/06/19	Copper	41	5	ppb	04/10/19	E200.8
CC90767	LP-23	04/06/19	Lead	0.8	0.5	ppb	04/10/19	E200.8
CC90768	LP-24	04/06/19	Copper	8	5	ppb	04/10/19	E200.8
CC90768	LP-24	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90769	LP-25	04/06/19	Copper	8	5	ppb	04/10/19	E200.8
CC90769	LP-25	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90770	LP-26	04/06/19	Copper	11	5	ppb	04/10/19	E200.8
CC90770	LP-26	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90771	LP-27	04/06/19	Copper	8	5	ppb	04/10/19	E200.8
CC90771	LP-27	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90772	LP-28	04/06/19	Copper	< 5	5	ppb	04/10/19	E200.8
CC90772	LP-28	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90773	LP-29	04/06/19	Copper	108	5	ppb	04/10/19	E200.8
CC90773	LP-29	04/06/19	Lead	11.6	0.5	ppb	04/10/19	E200.8
CC90774	LP-30	04/06/19	Copper	14	5	ppb	04/10/19	E200.8


Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CC90774	LP-30	04/06/19	Lead	0.5	0.5	ppb	04/10/19	E200.8
CC90775	LP-31	04/06/19	Copper	8	5	ppb	04/10/19	E200.8
CC90775	LP-31	04/06/19	Lead	1.4	0.5	ppb	04/10/19	E200.8
CC90776	LP-32	04/06/19	Copper	34	5	ppb	04/10/19	E200.8
CC90776	LP-32	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90777	LP-33	04/06/19	Copper	< 5	5	ppb	04/10/19	E200.8
CC90777	LP-33	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90778	LP-34	04/06/19	Copper	10	5	ppb	04/10/19	E200.8
CC90778	LP-34	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90779	LP-35	04/06/19	Copper	14	5	ppb	04/10/19	E200.8
CC90779	LP-35	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90780	LP-36	04/06/19	Copper	6	5	ppb	04/10/19	E200.8
CC90780	LP-36	04/06/19	Lead	< 0.5	0.5	ppb	04/10/19	E200.8
CC90781	LP-37	04/06/19	Copper	19	5	ppb	04/10/19	E200.8
CC90781	LP-37	04/06/19	Lead	2.5	0.5	ppb	04/10/19	E200.8
CC90782	LP-38	04/06/19	Copper	63	5	ppb	04/10/19	E200.8
CC90782	LP-38	04/06/19	Lead	24.8	0.5	ppb	04/10/19	E200.8
CC90783	LP-39	04/06/19	Copper	6	5	ppb	04/11/19	E200.8
CC90783	LP-39	04/06/19	Lead	< 0.5	0.5	ppb	04/11/19	E200.8
CC90784	LP-40	04/06/19	Copper	7	5	ppb	04/11/19	E200.8
CC90784	LP-40	04/06/19	Lead	< 0.5	0.5	ppb	04/11/19	E200.8
CC90785	LP-41	04/06/19	Copper	6	5	ppb	04/11/19	E200.8
CC90785	LP-41	04/06/19	Lead	< 0.5	0.5	ppb	04/11/19	E200.8
CC90786	LP-42	04/06/19	Copper	6	5	ppb	04/11/19	E200.8
CC90786	LP-42	04/06/19	Lead	< 0.5	0.5	ppb	04/11/19	E200.8
CC90787	LP-43	04/06/19	Copper	6	5	ppb	04/11/19	E200.8
CC90787	LP-43	04/06/19	Lead	< 0.5	0.5	ppb	04/11/19	E200.8
CC90788	LP-44	04/06/19	Copper	8	5	ppb	04/11/19	E200.8
CC90788	LP-44	04/06/19	Lead	< 0.5	0.5	ppb	04/11/19	E200.8
CC90789	LP-45	04/06/19	Copper	10	5	ppb	04/11/19	E200.8
CC90789	LP-45	04/06/19	Lead	0.5	0.5	ppb	04/11/19	E200.8
CC90790	LP-46	04/06/19	Copper	21	5	ppb	04/11/19	E200.8
CC90790	LP-46	04/06/19	Lead	< 0.5	0.5	ppb	04/11/19	E200.8
CC90791	LP-47	04/06/19	Copper	50	5	ppb	04/11/19	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CC90791	LP-47	04/06/19	Lead	6.2	0.5	ppb	04/11/19	E200.8
CC90792	LP-48	04/06/19	Copper	69	5	ppb	04/11/19	E200.8
CC90792	LP-48	04/06/19	Lead	3.1	0.5	ppb	04/11/19	E200.8
CC90793	LP-49	04/06/19	Copper	5	5	ppb	04/11/19	E200.8
CC90793	LP-49	04/06/19	Lead	< 0.5	0.5	ppb	04/11/19	E200.8

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit


Phyllis Shiller
Laboratory Director
April 12, 2019



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



QA/QC Report

April 12, 2019

QA/QC Data

SDG I.D.: GCC90745

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 473806A (mg/L), QC Sample No: CC89215 2X (CC90745, CC90746, CC90747, CC90748, CC90749)

ICP MS Metals - Aqueous

Copper	BRL	0.005				107			NC			85 - 115	20
Lead	BRL	0.0005				102			102			85 - 115	20

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 70-130%.

QA/QC Batch 474038 (mg/L), QC Sample No: CC90750 2X (CC90750, CC90751, CC90752, CC90753, CC90754, CC90755, CC90756, CC90757, CC90758)

ICP MS Metals - Aqueous

Copper	BRL	0.005	0.024	0.025	4.10	103			110			85 - 115	20
Lead	BRL	0.0005	<0.0005	<0.0005	NC	100			103			85 - 115	20

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 70-130%.

QA/QC Batch 474038A (mg/L), QC Sample No: CC90759 2X (CC90759, CC90760, CC90761, CC90762, CC90763, CC90764, CC90765, CC90766, CC90767, CC90768)

ICP MS Metals - Aqueous

Copper	BRL	0.005				103			104			85 - 115	20
Lead	BRL	0.0005				100			101			85 - 115	20

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 70-130%.

QA/QC Batch 474111 (mg/L), QC Sample No: CC90769 2X (CC90769, CC90770, CC90771, CC90772, CC90773, CC90774, CC90775, CC90776, CC90777, CC90778)

ICP MS Metals - Aqueous

Copper	BRL	0.005	0.008	0.009	NC	102			102			85 - 115	20
Lead	BRL	0.0005	<0.0005	<0.0005	NC	102			100			85 - 115	20

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 70-130%.

QA/QC Batch 474111A (mg/L), QC Sample No: CC90779 2X (CC90779, CC90780, CC90781, CC90782, CC90783, CC90784, CC90785)

ICP MS Metals - Aqueous

Copper	BRL	0.005				102			100			85 - 115	20
Lead	BRL	0.0005				102			99.0			85 - 115	20

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 70-130%.

QA/QC Data

SDG I.D.: GCC90745

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 474247 (mg/L), QC Sample No: CC90786 2X (CC90786, CC90787, CC90788, CC90789, CC90790, CC90791, CC90792, CC90793)

ICP MS Metals - Aqueous

Copper	BRL	0.005	0.006	0.006	NC	110			112			85 - 115	20
Lead	BRL	0.0005	<0.0005	<0.0005	NC	103			100			85 - 115	20

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 70-130%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

RPD - Relative Percent Difference

LCS - Laboratory Control Sample

LCSD - Laboratory Control Sample Duplicate

MS - Matrix Spike

MS Dup - Matrix Spike Duplicate

NC - No Criteria

Intf - Interference



Phyllis Shiller, Laboratory Director
April 12, 2019

Friday, April 12, 2019

Criteria: NJ: DW

State: NJ

Sample Criteria Exceedances Report

GCC90745 - MCCABE

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
CC90782	PB-DW-MS	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	24.8	0.5	15	1	ppb

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

April 12, 2019

SDG I.D.: GCC90745

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

1 of 5

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action

SITE ADDRESS: 330 Duncan Avenue, Jersey City, New Jersey

Lincoln Park

FIELD INSPECTOR'S NAME: Gary Clare

TURNAROUND TIME REQUESTED:

MES PROJECT #: 19-03619

SAMPLE DATE: 4/6/19

2 weeks

90745

90746

90747

90748

90749

90750

90751

90752

90753

90754

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	LP-01	Classroom 101 Food Prep Sink	8:45	COPPER - 200.7 LEAD - 200.8
DW	LP-02	Classroom 101 Water Fountain	8:47	COPPER - 200.7 LEAD - 200.8
DW	LP-03	Classroom 101/102 Bathroom Sink	8:50	COPPER - 200.7 LEAD - 200.8
DW	LP-04	Classroom 102 Food Prep Sink	8:52	COPPER - 200.7 LEAD - 200.8
DW	LP-05	Classroom 103 Food Prep Sink	8:55	COPPER - 200.7 LEAD - 200.8
DW	LP-06	Classroom 103 Water Fountain	8:59	COPPER - 200.7 LEAD - 200.8
DW	LP-07	Classroom 103 Bathroom Sink	8:59	COPPER - 200.7 LEAD - 200.8
DW	LP-08	Classroom 104 Food Prep Sink	9:02	COPPER - 200.7 LEAD - 200.8
DW	LP-09	Classroom 104 Water Fountain	9:04	COPPER - 200.7 LEAD - 200.8
DW	LP-10	Classroom 104/105 Bathroom Sink	9:07	COPPER - 200.7 LEAD - 200.8

Relinquished by (Print) Gary Clare	Date: 4/6/19	Time: 12:30pm	Received by (Print) BEAD CASSIDY	Date: 4-8	Time: 11:00
Signature: [Signature]			Signature: [Signature]		
Relinquished by (Print) BEAD CASSIDY	Date:	Time:	Received by (Print) MONICA PELTERNI	Date: 4/8/19	Time: 17:10
Signature: [Signature]			Signature: [Signature]		

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

Temp 21.3

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

2 of 5

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action		SITE ADDRESS: 330 Duncan Avenue, Jersey City, New Jersey Lincoln Park	
FIELD INSPECTOR'S NAME: Gary Clare		TURNAROUND TIME REQUESTED:	
MES PROJECT #: 19-03619	SAMPLE DATE: 4/6/19	2 weeks	

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	LP-11	Classroom 105 Food Prep Sink	9:15	COPPER - 200.7 LEAD - 200.8
DW	LP-12	Classroom 105 Water Fountain	9:17	COPPER - 200.7 LEAD - 200.8
DW	LP-13	Classroom 106 Food Prep Sink	9:19	COPPER - 200.7 LEAD - 200.8
DW	LP-14	Classroom 106 Water Fountain	9:21	COPPER - 200.7 LEAD - 200.8
DW	LP-15	Classroom 106/107 Bathroom Sink	9:23	COPPER - 200.7 LEAD - 200.8
DW	LP-16	Classroom 107 Food Prep Sink	9:26	COPPER - 200.7 LEAD - 200.8
DW	LP-17	Classroom 107 Water Fountain	9:29	COPPER - 200.7 LEAD - 200.8
DW	LP-18	2nd Floor Kitchen Sink (Left)	9:35	COPPER - 200.7 LEAD - 200.8
DW	LP-19	Classroom 202 Sink	9:40	COPPER - 200.7 LEAD - 200.8
DW	LP-20	Classroom 202 Water Fountain	9:45	COPPER - 200.7 LEAD - 200.8

Relinquished by (Print) Gary Clare	Date: 4/6/19	Time: 12:30pm	Received by (Print) BRAD CAPPY W	Date: 4-8-19	Time: 11:00
Signature: [Signature]			Signature: [Signature]		
Relinquished by (Print) BRAD CAPPY W	Date:	Time:	Received by (Print) MONICA J. PILLER	Date: 4/8/19	Time: 17:10
Signature: [Signature]			Signature: [Signature]		
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories					

McCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

3 of 5

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action

SITE ADDRESS: 330 Duncan Avenue, Jersey City, New Jersey

Lincoln Park

FIELD INSPECTOR'S NAME: Gary Clare





TURNAROUND TIME REQUESTED:

MES PROJECT #: 19-03619

SAMPLE DATE: 4/6/19

2 weeks

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
90765 DW	LP-21	Classroom 202 Bathroom Sink	9:50	COPPER - 200.7 LEAD - 200.8
90766 DW	LP-22	Classroom 203 Sink	9:52	COPPER - 200.7 LEAD - 200.8
90767 DW	LP-23	Classroom 203 Water Fountain	9:54	COPPER - 200.7 LEAD - 200.8
90768 DW	LP-24	Classroom 203 Bathroom Sink	9:57	COPPER - 200.7 LEAD - 200.8
90769 DW	LP-25	Classroom 204 Sink	9:59	COPPER - 200.7 LEAD - 200.8
90770 DW	LP-26	Classroom 204 Water Fountain	10:02	COPPER - 200.7 LEAD - 200.8
90771 DW	LP-27	Classroom 204 Bathroom Sink	10:04	COPPER - 200.7 LEAD - 200.8
90772 DW	LP-28	Main Office 205 Staff Bathroom Sink	10:05	COPPER - 200.7 LEAD - 200.8
90773 DW	LP-29	Main Office Room 208 Bathroom Sink	10:08	COPPER - 200.7 LEAD - 200.8
90774 DW	LP-30	Teacher Workroom 212 Sink	10:12	COPPER - 200.7 LEAD - 200.8

Relinquished by (Print) Gary Clare	Date: 4/6/19	Time: 12:30pm	Received by: (Print) BRAD GAFFYK	Date: 4-8-19	Time: 11:00
Signature: 			Signature: 		
Relinquished by (Print) BRAD GAFFYK	Date:	Time:	Received by: (Print) MONICA J. Pellen	Date: 4/8/19	Time: 17:10
Signature: 			Signature: 		
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories					

McCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

4 of 5

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action

SITE ADDRESS: 330 Duncan Avenue, Jersey City, New Jersey

Lincoln Park

FIELD INSPECTOR'S NAME: Gary Clare

TURNAROUND TIME REQUESTED:

MES PROJECT #: 19-03619

SAMPLE DATE:

4/6/19

2 weeks

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW 90775	LP-31	Teacher Workroom 212 Bathroom Sink	10:18	COPPER - 200.7 LEAD - 200.8
DW 90776	LP-32	Room 210 Water Fountain	10:23	COPPER - 200.7 LEAD - 200.8
DW 90777	LP-33	Room 210 Bathroom Sink	10:25	COPPER - 200.7 LEAD - 200.8
DW 90778	LP-34	Classroom 201 Sink	10:29	COPPER - 200.7 LEAD - 200.8
DW 90779	LP-35	Classroom 201 Water Fountain	10:32	COPPER - 200.7 LEAD - 200.8
DW 90780	LP-36	Classroom 201 Bathroom Sink	10:36	COPPER - 200.7 LEAD - 200.8
DW 90781	LP-37	2nd Floor Kitchen Sink (Right)	10:42	COPPER - 200.7 LEAD - 200.8
DW 90782	LP-38	2nd Floor Janitor Closet SJ1 Sink	10:48	COPPER - 200.7 LEAD - 200.8
DW 90783	LP-39	Classroom 101 Porcelain Sink	10:52	COPPER - 200.7 LEAD - 200.8
DW 90784	LP-40	Classroom 102 Porcelain Sink	10:56	COPPER - 200.7 LEAD - 200.8

Relinquished by (Print) Gary Clare	Date: 4/6/19	Time: 12:30pm	Received by (Print) BRAD CLARE	Date: 4-8-19	Time: 11:00
Signature: <i>[Signature]</i>			Signature: <i>[Signature]</i>		
Relinquished by (Print) BRAD CLARE	Date:	Time:	Received by (Print) MONICA J. Pellen	Date: 4/8/19	Time: 17:10
Signature: <i>[Signature]</i>			Signature: <i>[Signature]</i>		
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories					

21.3

McCabe Environmental Services, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

5055

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action

SITE ADDRESS: 330 Duncan Avenue, Jersey City, New Jersey

Lincoln Park

FIELD INSPECTOR'S NAME: Gary Clare

TURNAROUND TIME REQUESTED:

MES PROJECT #: 19-03619

SAMPLE DATE: 4/6/19

2 weeks

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
90785 DW	LP-41	Classroom 103 Porcelain Sink	11:00	COPPER - 200.7 LEAD - 200.8
90786 DW	LP-42	Classroom 104 Porcelain Sink	11:08	COPPER - 200.7 LEAD - 200.8
90787 DW	LP-43	Classroom 105 Porcelain Sink	11:09	COPPER - 200.7 LEAD - 200.8
90788 DW	LP-44	Classroom 106 Porcelain Sink	11:13	COPPER - 200.7 LEAD - 200.8
90789 DW	LP-45	Classroom 107 Porcelain Sink	11:16	COPPER - 200.7 LEAD - 200.8
90790 DW	LP-46	Classroom 102 Water Fountain	11:20	COPPER - 200.7 LEAD - 200.8
90791 DW	LP-47	2nd Floor Kitchen Handwashing Sink	11:24	COPPER - 200.7 LEAD - 200.8
90792 DW	LP-48	2nd Floor Nurses Office Sink	11:27	COPPER - 200.7 LEAD - 200.8
90793 DW	LP-49	1st Floor Janitors Closet FJ1-2 minute flush	11:34	COPPER - 200.7 LEAD - 200.8
90794 DW	MJO			COPPER - 200.7 LEAD - 200.8

Relinquished by (Print) Gary Clare	Date: 4/6/19	Time: 12:30pm	Received by (Print) BRAD CAFFEY	Date: 4-8-19	Time: 11:00
Signature: <i>[Signature]</i>			Signature: <i>[Signature]</i>		
Relinquished by (Print) BRAD CAFFEY	Date:	Time:	Received by (Print) MONICA Delleni	Date: 4/8/19	Time: 17:10
Signature: <i>[Signature]</i>			Signature: <i>[Signature]</i>		
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories					

NJ Certified WBE

Temp 21.3

APPENDIX B

SAMPLING PLAN ATTACHMENTS

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
CDCH Head Start	3/16/19	Phoenix Environmental Laboratories Inc.	
Passaic Head Start	3/16/19	Phoenix Environmental Laboratories Inc.	
Bergenfield Head Start	3/16/19	Phoenix Environmental Laboratories Inc.	
Cliffside Park Head Start	3/16/19 4/9/19	Phoenix Environmental Laboratories Inc.	
Eastside Head Start	3/16/19	Phoenix Environmental Laboratories Inc.	
Michaels Energy Factory	3/16/19	Phoenix Environmental Laboratories Inc.	
Westside Head Start	3/16/19	Phoenix Environmental Laboratories Inc.	
Bergen Institute Head Start	3/23/19	Phoenix Environmental Laboratories Inc.	
Bergen View Head Start	3/23/19	Phoenix Environmental Laboratories Inc.	
Bright Beginnings Head Start	3/23/19	Phoenix Environmental Laboratories Inc.	
Nelson 1 Head Start	3/23/19	Phoenix Environmental Laboratories Inc.	
Nelson Avenue Admin Head Start	3/23/19	Phoenix Environmental Laboratories Inc.	
St. John Head Start	3/23/19	Phoenix Environmental Laboratories Inc.	
Lincoln Park Head Start	4/6/19	Phoenix Environmental Laboratories Inc.	

Attachment B – Plumbing Profile

Note: Complete for each school. For additional information see the USEPA publication, “The 3Ts for Reducing Lead in Drinking Water in Schools”

Name of School: Lincoln Park Grade Levels: Childcare Facility

Address: 330 Duncan Avenue, Jersey City, New Jersey

Individual school project officer Signature: _____ Date: 06/10/19

Questions	Answers	
Background Information		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	2016	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Unknown	
3. Where are the most recent plumbing repairs and replacements?	Location: None	Description:
4. With what materials is the service connection (the pipe that carries water to the school from the public water system’s main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Coated Steel (Black w/ Ridges) Charlotte Pipe Location: Northeast Wall	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N Type:	Location:

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	No
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> • Name of contaminant(s) • Concentrations found • pH level Is testing done regularly at the building?	No
11. Other plumbing background questions include: <ul style="list-style-type: none"> • Are blueprints of the building available? • Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”? Are renovations planned for any of the plumbing system?	No

Questions	Answers
Walk-Through <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>	
1. Confirm the material of Service Line visually.	Done
2. Confirm the presence of POE or POU treatment.	Done
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> • Lead • Plastic • Galvanized Metal • Cast Iron • Copper • Other Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Copper & PVC
4. Are electrical wires grounded to Water Pipes? Note location(s).	<div>Y / N</div> <div>Location: Northeast Wall Electric Meter Room</div>
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory. Done

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N</p> <p>Type</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p> <p>No</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p>Permanently</p> <p>Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

Attachment C – Drinking Water Outlet Inventory

(Complete for each school)

Name of School: Lincoln Park

Address: 330 Duncan Avenue, Jersey City, New Jersey

Grade Levels: Childcare Facility

Year School Constructed: _____ Renovated/Additions: _____

Individual School Project Officer: Jeff Martin

Date Completed: April 10, 2019

# ¹	Type	Location	Code	Operational ² (Y/N)	Signs of Corrosion ³ (Y/N)	Filter ⁴ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Sink	Classroom 101 Food Prep Sink	LP-01	Y	N	N	N	Y	N	N	N/A	N/A	
02	Water Fountain	Classroom 101	LP-02	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
03	Sink	Classroom 101/102 Bathroom Sink	LP-03	Y	N	N	N	Y	N	N	N/A	N/A	
04	Sink	Classroom 102 Food Prep Sink	LP-04	Y	N	N	N	Y	N	N	N/A	N/A	
05	Sink	Classroom 103 Food Prep Sink	LP-05	Y	N	N	N	Y	N	N	N/A	N/A	
06	Water Fountain	Classroom 103	LP-06	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
07	Sink	Classroom 103	LP-07	Y	N	N	N	Y	N	N	N/A	N/A	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.

		Bathroom Sink											
08	Sink	Classroom 104 Food Prep Sink	LP-08	Y	N	N	N	Y	N	N	N/A	N/A	
09	Water Fountain	Classroom 104	LP-09	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
10	Sink	Classroom 104/105 Bathroom Sink	LP-010	Y	N	N	N	Y	N	N	N/A	N/A	
11	Sink	Classroom 105 Food Prep Sink	LP-11	Y	N	N	N	Y	N	N	N/A	N/A	
12	Water Fountain	Classroom 105	LP-12	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
13	Sink	Classroom 106 Food Prep Sink	LP-13	Y	N	N	N	Y	N	N	N/A	N/A	
14	Water Fountain	Classroom 106	LP-14	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
15	Sink	Classroom 106/107 Bathroom Sink	LP-15	Y	N	N	N	Y	N	N	N/A	N/A	
16	Sink	Classroom 107 Food Prep Sink	LP-16	Y	N	N	N	Y	N	N	N/A	N/A	
17	Water Fountain	Classroom 107	LP-17	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
18	Sink	2 nd Floor Kitchen Sink (Left)	LP-18	Y	N	N	N	Y	N	N	N/A	N/A	
19	Sink	Classroom 202	LP-19	Y	N	N	N	Y	N	N	N/A	N/A	
20	Water Fountain	Classroom 202	LP-20	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
21	Sink	Classroom 202 Bathroom Sink	LP-21	Y	N	N	N	Y	N	N	N/A	N/A	
22	Sink	Classroom 203	LP-22	Y	N	N	N	Y	N	N	N/A	N/A	

23	Water Fountain	Classroom 203	LP-23	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
24	Sink	Classroom 203 Bathroom Sink	LP-24	Y	N	N	N	Y	N	N	N/A	N/A	
25	Sink	Classroom 204	LP-25	Y	N	N	N	Y	N	N	N/A	N/A	
26	Water Fountain	Classroom 204	LP-26	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
27	Sink	Classroom 204 Bathroom Sink	LP-27	Y	N	N	N	Y	N	N	N/A	N/A	
28	Sink	Main Office 205 Staff Bathroom Sink	LP-28	Y	N	N	N	Y	N	N	N/A	N/A	
29	Sink	Main Office Room 208 Bathroom Sink	LP-29	Y	N	N	N	Y	N	N	N/A	N/A	
30	Sink	Teacher Workroom 212 Sink	LP-30	Y	N	N	N	Y	N	N	N/A	N/A	
31	Sink	Teacher Workroom 212 Bathroom Sink	LP-31	Y	N	N	N	Y	N	N	N/A	N/A	
32	Water Fountain	Room 210	LP-32	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
33	Sink	Room 210 Bathroom Sink	LP-33	Y	N	N	N	Y	N	N	N/A	N/A	
34	Sink	Classroom 201 Sink	LP-34	Y	N	N	N	Y	N	N	N/A	N/A	
35	Water Fountain	Classroom 201	LP-35	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
36	Sink	Classroom 201 Bathroom Sink	LP-36	Y	N	N	N	Y	N	N	N/A	N/A	
37	Sink	2 nd Floor	LP-37	Y	N	N	N	Y	N	N	N/A	N/A	

		Kitchen Sink (Right)											
38	Sink	2 nd Floor Janitor Closet SJ1 Sink	LP-38	Y	N	N	N	Y	N	N	N/A	N/A	
39	Sink	Classroom 101 Porcelain Sink	LP-39	Y	N	N	N	Y	N	N	N/A	N/A	
40	Sink	Classroom 102 Porcelain Sink	LP-40	Y	N	N	N	Y	N	N	N/A	N/A	
41	Sink	Classroom 103 Porcelain Sink	LP-41	Y	N	N	N	Y	N	N	N/A	N/A	
42	Sink	Classroom 104 Porcelain Sink	LP-42	Y	N	N	N	Y	N	N	N/A	N/A	
43	Sink	Classroom 105 Porcelain Sink	LP-43	Y	N	N	N	Y	N	N	N/A	N/A	
44	Sink	Classroom 106 Porcelain Sink	LP-44	Y	N	N	N	Y	N	N	N/A	N/A	
45	Sink	Classroom 107 Porcelain Sink	LP-45	Y	N	N	N	Y	N	N	N/A	N/A	
46	Water Fountain	Classroom 102	LP-46	Y	N	Y	N	N	N	Y	Elkay	LZSG8 1A	
47	Sink	2 nd Floor Kitchen Handwashing Sink	LP-47	Y	N	N	N	Y	N	N	N/A	N/A	
48	Sink	2 nd Floor Nurses Office Sink	LP-48	Y	N	N	N	Y	N	N	N/A	N/A	
49	Sink	1 st Floor Janitors Closet FJ1- 2 minute flush	LP-49	Y	N	N	N	Y	N	N	N/A	N/A	

Attachment D - Filter Inventory

(Complete for each school)

Name of School: Lincoln Park Grade Levels: Childcare FacilityAddress: 330 Duncan Avenue, Jersey City, New JerseyIndividual School Project Officer: Jeff MartinDate: April 10, 2019

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
LP-01	N/A	N/A	N/A	N/A	N/A
LP-02	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-03	N/A	N/A	N/A	N/A	N/A
LP-04	N/A	N/A	N/A	N/A	N/A
LP-05	N/A	N/A	N/A	N/A	N/A
LP-06	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-07	N/A	N/A	N/A	N/A	N/A
LP-08	N/A	N/A	N/A	N/A	N/A
LP-09	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-010	N/A	N/A	N/A	N/A	N/A
LP-11	N/A	N/A	N/A	N/A	N/A
LP-12	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-13	N/A	N/A	N/A	N/A	N/A
LP-14	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-15	N/A	N/A	N/A	N/A	N/A
LP-16	N/A	N/A	N/A	N/A	N/A
LP-17	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-18	N/A	N/A	N/A	N/A	N/A
LP-19	N/A	N/A	N/A	N/A	N/A
LP-20	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-21	N/A	N/A	N/A	N/A	N/A
LP-22	N/A	N/A	N/A	N/A	N/A
LP-23	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-24	N/A	N/A	N/A	N/A	N/A
LP-25	N/A	N/A	N/A	N/A	N/A
LP-26	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-27	N/A	N/A	N/A	N/A	N/A
LP-28	N/A	N/A	N/A	N/A	N/A

LP-29	N/A	N/A	N/A	N/A	N/A
LP-30	N/A	N/A	N/A	N/A	N/A
LP-31	N/A	N/A	N/A	N/A	N/A
LP-32	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-33	N/A	N/A	N/A	N/A	N/A
LP-34	N/A	N/A	N/A	N/A	N/A
LP-35	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-36	N/A	N/A	N/A	N/A	N/A
LP-37	N/A	N/A	N/A	N/A	N/A
LP-38	N/A	N/A	N/A	N/A	N/A
LP-39	N/A	N/A	N/A	N/A	N/A
LP-40	N/A	N/A	N/A	N/A	N/A
LP-41	N/A	N/A	N/A	N/A	N/A
LP-42	N/A	N/A	N/A	N/A	N/A
LP-43	N/A	N/A	N/A	N/A	N/A
LP-44	N/A	N/A	N/A	N/A	N/A
LP-45	N/A	N/A	N/A	N/A	N/A
LP-46	Elkay	LZSG8 1A	N/A	N/A	N/A
LP-47	N/A	N/A	N/A	N/A	N/A
LP-48	N/A	N/A	N/A	N/A	N/A
LP-49	N/A	N/A	N/A	N/A	N/A

Attachment E – Flushing Log
(Complete for each school as applicable)

Name of School: Lincoln Park

Address: 330 Duncan Avenue, Jersey City, New Jersey

Grade Levels: Childcare Facility

Individual School Project Officer: Jeff Martin

Date: April 10, 2019

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Classroom 101 Food Prep Sink	LP-01	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 101	LP-02	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 101/102 Bathroom Sink	LP-03	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 102 Food Prep Sink	LP-04	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 103 Food Prep Sink	LP-05	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 103	LP-06	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 103 Bathroom Sink	LP-07	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 104 Food Prep Sink	LP-08	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 104	LP-09	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 104/105 Bathroom Sink	LP-010	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 105 Food Prep Sink	LP-11	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 105	LP-12	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 106 Food Prep Sink	LP-13	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 106	LP-14	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 106/107 Bathroom Sink	LP-15	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 107 Food Prep Sink	LP-16	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling

Classroom 107	LP-17	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Kitchen Sink (Left)	LP-18	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 202	LP-19	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 202	LP-20	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 202 Bathroom Sink	LP-21	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 203	LP-22	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 203	LP-23	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 203 Bathroom Sink	LP-24	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 204	LP-25	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 204	LP-26	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 204 Bathroom Sink	LP-27	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Main Office 205 Staff Bathroom Sink	LP-28	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Main Office Room 208 Bathroom Sink	LP-29	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Teacher Workroom 212 Sink	LP-30	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Teacher Workroom 212 Bathroom Sink	LP-31	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Room 210	LP-32	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Room 210 Bathroom Sink	LP-33	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 201 Sink	LP-34	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 201	LP-35	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 201 Bathroom Sink	LP-36	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Kitchen Sink (Right)	LP-37	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Janitor Closet SJ1 Sink	LP-38	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 101 Porcelain Sink	LP-39	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 102 Porcelain Sink	LP-40	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling

Classroom 103 Porcelain Sink	LP-41	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 104 Porcelain Sink	LP-42	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 105 Porcelain Sink	LP-43	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 106 Porcelain Sink	LP-44	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 107 Porcelain Sink	LP-45	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
Classroom 102	LP-46	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Kitchen Handwashing Sink	LP-47	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
2 nd Floor Nurses Office Sink	LP-48	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling
1 st Floor Janitors Closet FJ1- 2 minute flush	LP-49	April 5, 2019	3:00 pm	2-3 minutes	Water Sampling

Attachment F - Pre - Sampling Water Use Certification

(Complete for each school)

TO BE COMPLETED BY THE LINCOLN PARK DISTRICT REPRESENTATIVE:		
School Name: Lincoln Park		
Sample collection address:	330 Duncan Avenue, Jersey City, New Jersey	
Water was last used:	Time: 3:00 pm	Date: April 5, 2019
Sample commencement:	Time: 8:45 am	Date: April 6, 2019
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Jeff Martin	04/10/19	
Signature	Date	