



464 Valley Brook Avenue, Lyndhurst NJ 07071
129 Sea Girt Avenue, Manasquan NJ 08736
Phone: (800) 423-0766 • Fax: (201) 438-1798
www.mccabeenv.com

LEAD & COPPER IN DRINKING WATER TESTING REPORT

Conducted for:

Greater Bergen Community Action
392 Main Street
Hackensack, New Jersey 07601

Conducted at:

Bright Beginnings Head Start
101 Nelson Avenue
Jersey City, New Jersey 07307

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: June 17, 2026

MES PROJECT NO.: 26-05491

Prepared by:

A handwritten signature in blue ink, reading 'Gerard D'Alessio'.

**Gerard D'Alessio
Environmental Scientist**

Signed for the Company by:

A handwritten signature in blue ink, reading 'John H. Chiaviello'.

**John H. Chiaviello
Vice President**

TABLE OF CONTENTS

	<u>Page</u>
1.0 INTRODUCTION	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS	2
5.0 DISCUSSION AND CONCLUSION	3

APPENDIX A

Laboratory Certificates of Analysis
&
Sample Chain of Custody Forms

APPENDIX B

Sample Location Drawing

APPENDIX C

Sampling Plan Attachments

1.0 INTRODUCTION

McCabe Environmental Services, L.L.C. (McCabe) was retained by Greater Bergen Community Action (Client) to conduct lead and copper in drinking water testing at 101 Nelson Avenue Head Start located at 101 Nelson Avenue, Jersey City, New Jersey 07307.

The project information is as follows:

Client Name: Greater Bergen Community Action
Contact Person: Mr. Raul Torres

Project Name: Bright Beginnings Head Start – Lead and Copper in Drinking Water Testing
Project Location: 101 Nelson Avenue
Jersey City, New Jersey 07307

Date(s) of Service: June 5th, 2026

McCabe Personnel: Kevin Brossok

2.0 SCOPE OF WORK

Drinking water testing was performed at 101 Nelson Avenue Head Start located at 101 Nelson Avenue, Jersey City, New Jersey 07307 on June 5th, 2026. The purpose of the testing was to determine if the building's plumbing was having an adverse impact on water quality, specifically with regard to lead and copper concentrations. Samples were collected from various potential drinking water outlets located throughout the building.

3.0 PROCEDURES

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one-liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

4.0 TABLE OF SAMPLE RESULTS

The following table presents all sample results in order of sample identification:

Lead & Copper in Drinking Water – Sample Results						
Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
01	Classroom 2 Food Prep Sink	< 1	Pass	Pass	31	Pass
02	Classroom 2 Bathroom Sink Left	< 1	Pass	Pass	26	Pass
03	Classroom 2 Hand Washing Sink	< 1	Pass	Pass	23	Pass
04	Classroom 2 Bathroom Sink Right	< 1	Pass	Pass	31	Pass
05	Classroom 3 Food Prep Sink	< 1	Pass	Pass	24	Pass
06	Classroom 3 Handwashing Sink	< 1	Pass	Pass	23	Pass
07	Bathroom between Classrooms 1 and 3 Left Sink	< 1	Pass	Pass	23	Pass
08	Bathroom between Classrooms 1 and 3 Right Sink	< 1	Pass	Pass	21	Pass
09	Classroom 1 Food Prep Sink	< 1	Pass	Pass	25	Pass
10	Classroom 1 Hand Washing Sink	< 1	Pass	Pass	17	Pass
11	2 nd Floor Staff Lounge Bathroom	< 1	Pass	Pass	63	Pass
12	2 nd Floor Staff Lounge Kitchen	< 1	Pass	Pass	79	Pass

5.0 DISCUSSION AND CONCLUSION

A total of twelve (12) samples were collected on June 5, 2026 from Bright Beginnings Head Start located at 101 Nelson Avenue, Jersey City, New Jersey 07307. All samples were found to be less than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb, as well as the EPA Lead and Copper Rule standard of 15 ppb. All samples were also found to be less than the 1300ppb standard for copper.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building's plumbing is not having an adverse impact on water quality.

APPENDIX A

**LABORATORY CERTIFICATES OF ANALYSIS
&
SAMPLE CHAIN OF CUSTODY FORMS**



Monday, June 15, 2026

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: GREATER BERGEN COMMUNITY ACTION
SDG ID: GCW15817
Sample ID#s: CW15817 - CW15828

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Phyllis Shiller".

Phyllis Shiller

Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

June 15, 2026

SDG I.D.: GCW15817

Project ID: GREATER BERGEN COMMUNITY ACTION

Client Id	Lab Id	Matrix	Col Date
01	CW15817	DRINKING WATER	06/05/26 7:48
02	CW15818	DRINKING WATER	06/05/26 7:50
03	CW15819	DRINKING WATER	06/05/26 7:52
04	CW15820	DRINKING WATER	06/05/26 7:54
05	CW15821	DRINKING WATER	06/05/26 7:26
06	CW15822	DRINKING WATER	06/05/26 7:28
07	CW15823	DRINKING WATER	06/05/26 7:30
08	CW15824	DRINKING WATER	06/05/26 7:32
09	CW15825	DRINKING WATER	06/05/26 7:34
10	CW15826	DRINKING WATER	06/05/26 7:36
11	CW15827	DRINKING WATER	06/05/26 7:40
12	CW15828	DRINKING WATER	06/05/26 7:44



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:48
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15817

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	31	2	1	ppb	1300		1000	06/12/26	TH	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	TH	E200.5
Total Metal Digestion	Completed							06/10/26	BF/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:50
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15818

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	26	2	1	ppb	1300		1000	06/12/26	TH	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	TH	E200.5
Total Metal Digestion	Completed							06/10/26	BF/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:52
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15819

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	23	2	1	ppb	1300		1000	06/12/26	TH	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	TH	E200.5
Total Metal Digestion	Completed							06/10/26	BF/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:54
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15820

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	31	2	1	ppb	1300		1000	06/12/26	TH	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	TH	E200.5
Total Metal Digestion	Completed							06/10/26	BF/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:26
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15821

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	24	2	1	ppb	1300		1000	06/12/26	TH	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	TH	E200.5
Total Metal Digestion	Completed							06/10/26	BF/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:28
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15822

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	23	2	1	ppb	1300		1000	06/12/26	TH	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	TH	E200.5
Total Metal Digestion	Completed							06/11/26	AG/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:30
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15823

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	23	2	1	ppb	1300		1000	06/12/26	th	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	th	E200.5
Total Metal Digestion	Completed							06/11/26	AG/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:32
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15824

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	21	2	1	ppb	1300		1000	06/12/26	th	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	th	E200.5
Total Metal Digestion	Completed							06/11/26	AG/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:34
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15825

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	25	2	1	ppb	1300		1000	06/12/26	th	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	th	E200.5
Total Metal Digestion	Completed							06/11/26	AG/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:36
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15826

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	17	2	1	ppb	1300		1000	06/12/26	th	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	th	E200.5
Total Metal Digestion	Completed							06/11/26	AG/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:40
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15827

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	63	2	1	ppb	1300		1000	06/12/26	th	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	th	E200.5
Total Metal Digestion	Completed							06/11/26	AG/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

June 15, 2026

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 26-05491

Custody Information

Collected by: KB
Received by: SR1
Analyzed by: see "By" below

Date

06/05/26
06/05/26

Time

7:44
18:00

Laboratory Data

SDG ID: GCW15817
Phoenix ID: CW15828

Project ID: GREATER BERGEN COMMUNITY ACTION
Client ID: 12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	79	2	1	ppb	1300		1000	06/12/26	th	E200.7
Lead	< 1	1	1	ppb	15			06/12/26	th	E200.5
Total Metal Digestion	Completed							06/11/26	AG/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 15, 2026

Reviewed and Released by: Anil Makol, Project Manager

Analysis Report - Summary

June 15, 2026

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCW15817



Sample	Client Id	Col Date	Parameter	Result	RL	CL	Units	Date Analyzed	Reference
Project: Greater Bergen Community Action									
CW15817	01	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15818	02	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15819	03	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15820	04	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15821	05	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15822	06	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15823	07	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15824	08	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15825	09	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15826	10	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15827	11	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5
CW15828	12	06/05/26	Lead	< 1	1		ppb	06/12/26	E200.5

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit


Phyllis Shiller
Laboratory Director
June 15, 2026



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



QA/QC Report

June 15, 2026

QA/QC Data

SDG I.D.: GCW15817

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 844932A (mg/L), QC Sample No: CW14170 (CW15817, CW15818, CW15819, CW15820, CW15821)

ICP Metals - Aqueous

Copper	BRL	0.0020				106			106			85 - 115	20
Lead	BRL	0.0010				105			102			85 - 115	20

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 845127 (mg/L), QC Sample No: CW15822 (CW15822)

ICP Metals - Aqueous

Copper	BRL	0.0020	0.023	0.0225	2.20	103			103			85 - 115	20
Lead	BRL	0.0010	<0.0010	<0.0010	NC	106			103			85 - 115	20

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 845128 (mg/L), QC Sample No: CW15823 (CW15823, CW15824, CW15825, CW15826, CW15827, CW15828)

ICP Metals - Aqueous

Copper	BRL	0.0020	0.023	0.0236	2.60	102			104			85 - 115	20
Lead	BRL	0.0010	<0.0010	<0.0010	NC	106			106			85 - 115	20

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


Phyllis Shiller, Laboratory Director
June 15, 2026

Monday, June 15, 2026

Criteria: NJ: DW
State: NJ

Sample Criteria Exceedances Report
GCW15817 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

June 15, 2026

SDG I.D.: GCW15817

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

McCabe Environmental Services, L.L.C.

464 Valley Brook Avenue Lyndhurst, NJ 07071 • PHONE: (201) 438-4839 FAX: (201) 438-1798

LEAD & COPPER in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Greater Bergen Community Action		SITE ADDRESS: 101 Nelson Avenue, Jersey City, New Jersey 07307	
FIELD INSPECTOR'S NAME: <u>Kevin Brosnok</u>		TURNAROUND TIME REQUESTED: 2 Weeks	
MES PROJECT #: 26-05491		SAMPLE DATE: <u>6/5/26</u>	
Matrix	SAMPLE ID	SAMPLE LOCATION	ANALYSIS REQUESTED
DW	15817 01	Classroom 2 Food Prep Sink	COPPER - 200.7 LEAD - 200.8
DW	15818 02	Classroom 2 Bathroom Sink Left	COPPER - 200.7 LEAD - 200.8
DW	15819 03	Classroom 2 Hand Washing Sink	COPPER - 200.7 LEAD - 200.8
DW	15820 04	Classroom 2 Bathroom Sink Right	COPPER - 200.7 LEAD - 200.8
DW	15821 05	Classroom 3 Food Prep Sink	COPPER - 200.7 LEAD - 200.8
DW	15822 06	Classroom 3 Handwashing Sink	COPPER - 200.7 LEAD - 200.8
DW	15823 07	Bathroom between Classrooms 1 and 3 Left Sink	COPPER - 200.7 LEAD - 200.8
DW	15824 08	Bathroom between Classrooms 1 and 3 Right Sink	COPPER - 200.7 LEAD - 200.8
DW	15825 09	Classroom 1 Food Prep Sink	COPPER - 200.7 LEAD - 200.8
DW	15826 10	Classroom 1 Hand Washing Sink	COPPER - 200.7 LEAD - 200.8
Relinquished by (Print) <u>Kevin Brosnok</u>		Date: <u>6/5/26</u>	Time: <u>9:00 AM</u>
Signature: <u>[Signature]</u>		Received by: (Print) <u>[Signature]</u>	Signature: <u>[Signature]</u>
Relinquished by (Print) <u>[Signature]</u>		Date: <u>6/5/26</u>	Time: <u>11:11</u>
Signature: <u>[Signature]</u>		Received by: (Print) <u>[Signature]</u>	Signature: <u>[Signature]</u>
Relinquished by (Print) <u>[Signature]</u>		Date: <u>6/5/26</u>	Time: <u>18:00</u>
Signature: <u>[Signature]</u>		Received by: (Print) <u>[Signature]</u>	Signature: <u>[Signature]</u>
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories			

NJ Certified WBE

1.8°C
WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD & COPPER in DRINKING WATER									
CHAIN-OF-CUSTODY FORM					SITE ADDRESS: 101 Nelson Avenue, Jersey City, New Jersey 07307				
CLIENT NAME: Greater Bergen Community Action					TURNAROUND TIME REQUESTED: 2 Weeks				
FIELD INSPECTOR'S NAME: Kevin Rossok									
MES PROJECT #: 26-05491		SAMPLE DATE: 6/5/26							
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED					
DW	15821	11 2nd Floor Staff Lounge Bathroom	7:40	COPPER - 200.7 LEAD - 200.8					
DW	15828	12 2nd Floor Staff Lounge Kitchen	7:44	COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
DW				COPPER - 200.7 LEAD - 200.8					
Relinquished by (Print) Kevin Rossok		Date: 6/5/26	Time: 9:00 AM	Received by: (Print) [Signature]	Date: 6/6/26	Time: 11:11			
Signature: [Signature]				Signature:					
Relinquished by (Print) [Signature]		Date:	Time:	Received by: (Print) [Signature]	Date: 6/5/26	Time: 18:00			
Signature: [Signature]				Signature:					
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories									

NJ Certified WBE

APPENDIX B

SAMPLE LOCATION DRAWING

APPENDIX C

SAMPLING PLAN ATTACHMENTS

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
101 Nelson Avenue Head Start	06/05/26	Phoenix Environmental Laboratories Inc.	

Attachment B – Plumbing Profile

Note: Complete for each school. For additional information see the USEPA publication, “The 3Ts for Reducing Lead in Drinking Water in Schools”

Name of School: 101 Nelson Avenue Head Start Grade Levels: Childcare Center

Address: 101 Nelson Avenue, Jersey City, NJ 07307

Individual school project officer Signature: Raul Torres Date: 06/05/2026

Questions	Answers	
Background Information		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	1910 No	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.		
3. Where are the most recent plumbing repairs and replacements?	Location: On the First Floor	Description: Complete Renovation 2015
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Location: North/East - Corner Of Basement	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N Type:	Location:

Questions	Answers	
7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit? Recalled Drinking Water Fountains Make and Model	Y / N Type	
8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected? Note the locations of water outlets.	Complete in “Signs of Corrosion” column in Attachment C- Drinking Water Outlet Inventory. No	
9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily? Permanently Temporarily	Y / N Complete “Operational Column” in Attachment C- Drinking Water Outlet Inventory. Type/ Location	Description

Attachment C – Drinking Water Outlet Inventory

Name of School: 101 Nelson Avenue Head Start

Address: 101 Nelson Avenue, Jersey City, New Jersey

Grade Levels: Childcare Facility

Year School Constructed: NA Renovated/Additions: _____

Individual School Project Officer: Mr. Raul Torres

Date Completed: June 5, 2026

# ¹	Type	Location	Code	Operational ² (Y/N)	Signs of Corrosion ³ (Y/N)	Filter ⁴ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Sink	Classroom 2 Food Prep Sink	01	Y	N	N	N	Y	N	N	N/A	N/A	
02	Sink	Classroom 2 Bathroom Sink Left	02	Y	N	N	N	Y	N	N	N/A	N/A	
03	Sink	Classroom 2 Hand Washing Sink	03	Y	N	N	N	Y	N	N	N/A	N/A	
04	Sink	Classroom 2 Bathroom Sink Right	04	Y	N	N	N	Y	N	N	N/A	N/A	
05	Sink	Classroom 3 Food Prep Sink	05	Y	N	N	N	Y	N	N	N/A	N/A	
06	Sink	Classroom 3 Handwashing	06	Y	N	N	N	Y	N	N	N/A	N/A	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.

		Sink											
07	Sink	Bathroom between Classrooms 1 and 3 Left Sink	07	Y	N	N	N	Y	N	N	N/A	N/A	
08	Sink	Bathroom between Classrooms 1 and 3 Right Sink	08	Y	N	N	N	Y	N	N	N/A	N/A	
09	Sink	Classroom 1 Food Prep Sink	09	Y	N	N	N	Y	N	N	N/A	N/A	
10	Sink	Classroom 1 Hand Washing Sink	10	Y	N	N	N	Y	N	N	N/A	N/A	
11	Sink	2nd Floor Staff Lounge Bathroom	11	Y	N	N	N	Y	N	N	N/A	N/A	
12	Sink	2nd Floor Staff Lounge Kitchen	12	Y	N	N	N	Y	N	N	N/A	N/A	

Attachment D - Filter Inventory

Name of School: 101 Nelson Avenue Head Start Grade Levels: Childcare Facility

Address: 101 Nelson Avenue, Jersey City, New Jersey

Individual School Project Officer: Mr. Raul Torres Date: June 5, 2026

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
Classroom 2 Food Prep Sink	N/A	N/A	N/A	N/A	N/A
Classroom 2 Bathroom Sink Left	N/A	N/A	N/A	N/A	N/A
Classroom 2 Hand Washing Sink	N/A	N/A	N/A	N/A	N/A
Classroom 2 Bathroom Sink Right	N/A	N/A	N/A	N/A	N/A
Classroom 3 Food Prep Sink	N/A	N/A	N/A	N/A	N/A
Classroom 3 Handwashing Sink	N/A	N/A	N/A	N/A	N/A
Bathroom between Classrooms 1 and 3 Left Sink	N/A	N/A	N/A	N/A	N/A
Bathroom between Classrooms 1 and 3 Right Sink	N/A	N/A	N/A	N/A	N/A
Classroom 1 Food Prep Sink	N/A	N/A	N/A	N/A	N/A
Classroom 1 Hand Washing Sink	N/A	N/A	N/A	N/A	N/A
2nd Floor Staff Lounge Bathroom	N/A	N/A	N/A	N/A	N/A
2nd Floor Staff Lounge Kitchen	N/A	N/A	N/A	N/A	N/A

Attachment E – Flushing Log

Name of School: 101 Nelson Avenue Head Start

Address: 101 Nelson Avenue, Jersey City, New Jersey

Grade Levels: Childcare Facility

Individual School Project Officer: Mr. Raul Torres

Date: June 5, 2026

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Classroom 2 Food Prep Sink	01	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
Classroom 2 Bathroom Sink Left	02	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
Classroom 2 Hand Washing Sink	03	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
Classroom 2 Bathroom Sink Right	04	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
Classroom 3 Food Prep Sink	05	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
Classroom 3 Handwashing Sink	06	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
Bathroom between Classrooms 1 and 3 Left Sink	07	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
Bathroom between Classrooms 1 and 3 Right Sink	08	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
Classroom 1 Food Prep Sink	09	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
Classroom 1 Hand Washing Sink	10	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
2nd Floor Staff Lounge Bathroom	11	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling
2nd Floor Staff Lounge Kitchen	12	June 4, 2026	3:00 pm	2-3 minutes	Water Sampling

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BRIGHT BEGINNINGS DISTRICT REPRESENTATIVE:		
School Name: Bright Beginnings		
Sample collection address:	101 Nelson Avenue, Jersey City, New Jersey	
Water was last used:	Time: 3:00 pm	Date: June 4, 2026
Sample commencement:	Time: 7:20 am	Date: June 5, 2026
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Raul Torres	06/05/2026	
Signature	Date	

DRINKING WATER TESTING CHECKLIST

Note: This form is for child care centers that are supplied water by a community water system.

•PROGRAMS IN OPERATING PUBLIC SCHOOLS ARE NOT REQUIRED TO COMPLETE THIS FORM•

CHILD CARE CENTER INFORMATION

Name of Child Care Center:		License ID:	
Bright Beginnings Head Start			
Site Address of Center:	Building # and Street:	Municipality:	County:
	101 Nelson Avenue	Jersey City	Hudson County
Sponsor/Sponsor Representative:		Phone Number:	Email:
		201-968-0200	raul.torres@greaterbergen.org

CERTIFICATION OF COMPLIANCE WITH LEAD & COPPER SAMPLING AT THE ABOVE CHILD CARE CENTER

Sampling Date(s):	June 5, 2023
1. ☐ YES ☐ NO	Does the center have a signed contract with a New Jersey Certified Drinking Water Laboratory for lead & copper analysis?
2. ☐ YES ☐ NO	Is there an onsite water outlet assessment in accordance with technical guidance?
3. ☐ YES ☐ NO	Is there a floor plan in accordance with technical guidance?
4. ☐ YES ☐ NO Sample Date:	Were all the drinking water outlets in the center where a child or staff has or may have access (including food preparation and outside drinking water outlets) sampled?
5. ☐ YES ☐ NO Sample Date:	Were at least 50% of all indoor water faucets utilized by the center sampled?
6. ☐ YES ☐ NO	Does the child care center have the chain of custody and analytical reports for all drinking water outlets sampled? Please attach copies.
7. ☐ YES ☐ NO	Was all the drinking water outlets sampled in the sequence determined by the floor plan beginning with the outlet closest to the point of entry?
8. ☐ YES ☐ NO	Were all samples taken after the water sat undisturbed in pipes for at least 8 hours but no more than 48 hours?
9. ☐ YES ☐ NO	Were samples collected in pre-cleaned high density polyethylene (HDPE) 250 ml wide mouth single use rigid sample containers?
10. ☐ YES ☐ NO	Were all existing aerators, screens, and filters left in place prior to and during the sampling event?
11. ☐ YES ☐ NO	Were only cold water samples collected?
12. ☐ YES ☐ NO	Did no pre-stagnant flushing take place unless the outlet deviated from normal use and documented on flushing log?
13. ☐ YES ☐ NO	Was all point of use treatment on outlets, such as filters, documented?
14. ☐ YES ☐ NO	Did any result exceed the action level for lead (15 µg/L) or copper (1300 µg/L)?
15. ☐ YES ☐ NO ☐ N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) was use of all drinking water outlets immediately discontinued?
16. ☐ YES ☐ NO ☐ N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) was bottled water provided for drinking and food preparation?
17. ☐ YES ☐ NO ☐ N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) were signs posted to indicate that the outlets are not to be used for drinking or food preparation?

18. ☐ YES ☐ NO ☐ N/A	Did all drinking water outlets with a result that exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) have a follow-up flush sample conducted?
19. ☐ YES ☐ NO ☐ N/A	If a result exceeded the action level for lead (15 µg/L) or copper (1300 µg/L) was the local health office notified of results?
20. ☐ YES ☐ NO ☐ N/A	If any of the results exceeded the action level for lead (15 µg/L) or copper (1300 µg/L), was notification, including results and remediation measures, provided to the parent(s) of all children attending the center, the staff, and NJDCF?
21. ☐ YES ☐ NO ☐ N/A	Were any drinking water outlets or potable plumbing replaced or repaired as a remedy for an action level exceedance?
22. ☐ YES ☐ NO ☐ N/A Sample Date:	If any drinking water outlet or potable plumbing was replaced or repaired, were additional samples collected after installation?
23. ☐ YES ☐ NO ☐ N/A	Was any chemical treatment unit or process installed to remedy an action level exceedance (e.g., corrosion control treatment)?
24. ☐ YES ☐ NO ☐ N/A Sample Date:	If a chemical treatment unit or process was installed to remedy an action level exceedance (e.g., corrosion control treatment), were additional samples collected after the installation?
25. ☐ YES ☐ NO ☐ N/A	Was a mechanical process implemented to remedy an action level exceedance (e.g., flushing program)?
26. ☐ YES ☐ NO ☐ N/A	If a mechanical process was implemented to remedy an action level exceedance (e.g., flushing program), were additional samples collected after the implementation?
27. ☐ YES ☐ NO ☐ N/A	If no remedial action was taken, such as those indicated in 21 through 26 above, has the center implemented a written plan of action for use of bottled water for drinking and food preparation?

CERTIFICATION: By signing below, the **Sponsor or Sponsor Representative** certifies that all answers on this checklist are true and accurate:

Sponsor/Sponsor Representative: (PRINT)	
Signature:	
Signature Date:	

DRINKING WATER TESTING RESOURCES

Schools - Lead Sampling Information

<http://www.nj.gov/dep/watersupply/schools.htm>

Lead Sampling in Schools Technical Guidance FAQs

<http://www.nj.gov/dep/watersupply/pdf/leadfaq.pdf>

3Ts for Reducing Lead in Drinking Water: Testing

<https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-testing>

Quick Reference Guide Sampling For Lead in Drinking Water in Schools:

<http://www.nj.gov/dep/watersupply/pdf/quickref.pdf>

List of NJ Certified Laboratories:

<https://www13.state.nj.us/DataMiner/Search/SearchByCategory?isExternal=y&getCategory=y&catName=Certified+Laboratories>

Drinking Water Outlet Inventory Form:

http://www.nj.gov/dep/watersupply/doc/SP_Attachment%20C.docx

Sampling Water Use Certification:

http://www.nj.gov/dep/watersupply/doc/SP_Attachment%20F.docx

Filter Inventory Form:

http://www.nj.gov/dep/watersupply/doc/SP_Attachment%20D.docx

Results Letter Template:

<http://www.nj.gov/dep/watersupply/doc/resultsletter.doc>